



This report is not valid if the serial number has been defaced or altered

21773956 IPN18C

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

Original (to the person ordering the work)

PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR	DETAILS OF THE CLIENT	DETAILS OF THE INSTALLATION
Registration No: 604880000 Branch No: 000	Contractor Reference Number (CRN): N/A	Occupier: CRM Kingston Plaza
Trading Title: Kiasu Consulting Ltd	Name: CRM Kingston Plaza	Address: 180-190 London Road, Kingston Upon Thames, London, London
Address: Unit G, Great Hollenden Business, Mill Lane, Underriver, Sevenoaks	Address: 180-190 London Road, Kingston Upon Thames, London, London	Postcode: KT2 6QW Tel No: N/A
Postcode: TN15 0SQ Tel No: 02089881662	Postcode: KT2 6QW Tel No: N/A	

PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required: 5 Year EICR at Request of Client

Date(s) when inspection and testing was carried out: (12/08/2020) Records available: (✓) Previous inspection report available: (✓) Previous report date: (14/09/2014)

PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):
 Very low Zs readings due to Parallel paths on CPC's. General conditions of the installations is good. Number of C3 recommendations. The DB's used in this installation are Hager.

Estimated age of electrical installation: (5) years Evidence of additions or alterations: (x) Overall assessment of the installation is: ~~Satisfactory~~ ~~Unsatisfactory~~ * (delete as appropriate)

PART 4 : DECLARATION

INSPECTION AND TESTING

I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 7, having exercised reasonable skill and care when carrying out the inspection and testing of the existing installation, hereby CERTIFY that the information in this report, including the observations (page 2) and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

Name (capitals): CHRIS SPARKS Signature: [Signature] Date: 17/08/2020

REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE APPROVED CONTRACTOR

Name (capitals): CHRIS SPARKS Signature: [Signature] Date: 17/08/2020

*An unsatisfactory assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified in PART 6, or that Further Investigation (CODE FI) without delay is required.

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 5 : NEXT INSPECTION

I/We (as indicated on page 1) recommend, subject to the necessary remedial work being taken, this installation should be further inspected and tested after an interval of not more than 5 years/~~XXXX~~* (delete as appropriate)
 Give reason for recommendation: 5 Year or change of tenant

PART 6 : OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

CODES:	CODE C1 'Danger Present' Risk of injury. Immediate remedial action required	CODE C2 'Potentially Dangerous' Urgent remedial action required	CODE C3 'Improvement Recommended'	CODE FI 'Further Investigation Required'
<p><i>One of the following Codes, as appropriate, has been allocated to each of the observations made below to indicate to the person(s) responsible for the electrical installation the degree of urgency for remedial action</i></p> <p>Referring to the Schedule of Items Inspected (see PART 10), the attached Schedule of Circuit Details and Test Results (see PART 12), and subject to any agreed limitations listed in PART 7:</p> <p>There are no items adversely affecting electrical safety (XXXX), OR The following observations and recommendations for action are made:</p>				
Item No	Observation(s)	Code	Location Reference	
1	Supplies to DB's From Main Electrical Panel Using armoured sheath as earth, All Sheaths are linked via 6mm cable with only one fly lead back to earthing terminal in DB. all SWA Should have there own Fly lead with appropriate size of CPC connected.	C3	Main Electrical DB	
2	Circuit 5L2. End To End continuity on r1 open circuits, Broken Ring. Live found in back of switch plate in kitchen re-connected. Fixed on site	✓	Ground Floor Power	
3	16mm Earthing cable daisy chained up through sub mains boards on each floor. Recommended that each board has its own earthing cable	C3	Sub mains	
4	Light in Hallway not working	C3	Studio 1.13	
5	x1 Missing DB front cover screw	C3	Ground Floor Power	
6	x1 Missing DB front cover screw	C3	First Floor Power	
7	x1 Missing DB front cover screw	C3	Plant Room Power	
8	x1 Outside Light by back door requires re-fixing.	C3	Outside Light	
9	Ground Floor Common area x1 Light fitting not working	C3	Ground Floor	
10	x1 Missing DB front cover screw	C3	Second Floor DB	
11	Screed from the floor above has leaked down the cable run and into the DB	C3	Second Floor DB	
12	x1 Missing DB front cover screw	C3	Third Floor DB	
13	x2 Missing DB front cover screw	C3	Fourth Floor DB	
14	Broken Microwave Switch	C3	Studio 3-11	
(.....)	(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)	(.....)
(.....)	(.....)	(.....)	(.....)	(.....)
Additional pages? (<u>None</u>) State page numbers: (<u>N/A</u>)				
Immediate action required for items: (<u>N/A</u>)		Improvement recommended for items: (<u>1,3,4,5,6,7,8,9,10,11,12,13,14</u>)		
Urgent remedial action required for items: (<u>N/A</u>)		Further investigation required for items: (<u>N/A</u>)		

*The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

Original (to the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 7 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671: 2018, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the installation covered by this report: 100% of the installation with 10% of accessories removed for visual inspection (see additional page No. N/A)

Agreed limitations including the reasons, if any, on the inspection and testing: Insulation resistant test carried out with line and neutral connected to earth.

Extent of sampling: (see additional page No. N/A)

Operational limitations including the reasons: No access to some locked rooms, No Access to Laundry Isolators and Circuits behind dryers and washing machines. (see additional page No. N/A)

PART 8 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System type and earthing arrangements	Number and type of live conductors	Nature of supply parameters
TN-C-S: (N/A) TN-S: (✓) TT: (N/A)	AC 1-phase, 2-wire: (N/A) 2-phase, 3-wire: (N/A)	Nominal line voltage, $U^{(1)}$: (400) V
Other (state): N/A	3-phase, 3-wire: (N/A) 3-phase, 4-wire: (✓)	Nominal line voltage to Earth, $U_0^{(1)}$: (230) V
Supply protective device	DC 2-wire: (N/A) 3-wire: (N/A) Other: (N/A)	Nominal frequency, $f^{(1)}$: (50) Hz
(BS (EN) 1361)	Confirmation of supply polarity: (✓)	Prospective fault current, $I_{pf}^{(1)*}$: (9.2) kA
Type: (II) Rated current: (315) A	Other sources of supply (as detailed on attached schedule) Page No: (N/A)	External loop impedance, $Z_e^{(1)*}$: (0.06) Ω

PART 9 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of Earthing	Main protective conductors	Main protective bonding connections	Main switch / Switch-fuse / Circuit-breaker / RCD
Distributor's facility: (✓)	Earthing conductor:	Water installation pipes: (✓)	Type: (BS (EN) 60947-3)
Installation earth electrode: (N/A)	(material Copper) csa 50 mm ²	Gas installation pipes: (✓)	Location: (Mains Cupboard)
Where an earth electrode is used insert	Connection / continuity verified: (✓)	Structural steel: (✓)	No. of poles: (4) Rating / setting of device: (400) A
Type – rod(s), tape, etc: (None)	Main protective bonding conductors:	Oil installation pipes: (N/A)	Current rating: (400) A Voltage rating: (400) V
Location: (N/A)	(material Copper) csa 25 mm ²	Lightning protection: (✓)	Where an RCD is used as the main switch
Electrode resistance to Earth: (N/A) Ω	Connection / continuity verified: (✓)	Other (state): (N/A)	RCD rated residual operating current, $I_{\Delta n}$: (N/A) mA
			Measured operating time: (N/A) ms Rated time delay: (N/A) ms

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I_{pf} , and external earth fault loop impedance, Z_e , must be recorded.

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately – CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 10 : SCHEDULE OF ITEMS INSPECTED

1. External condition of electrical intake equipment (visual inspection only) (If inadequacies are identified with the intake equipment, it is recommended the person ordering the report informs the appropriate authority.)		4. Other methods of protection (N/A)		5.24 Single-pole switching or protective devices in line conductors only: (✓)	
		Details should be provided on separate sheets: Page No. (N/A)		5.25 Protection against mechanical damage where cables enter equipment: (✓)	
2. Presence of adequate arrangements for parallel or switched alternative sources		5. Distribution equipment		5.26 Protection against electromagnetic effects where cables enter ferromagnetic enclosures: (✓)	
2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply: (N/A)		5.1 Adequacy of working space / accessibility of equipment: (✓)		6. Distribution / final circuits	
2.2 Adequate arrangements where generating set operates in parallel with the public supply: (N/A)		5.2 Security of fixing: (✓)		6.1 Identification of conductors: (✓)	
2.3 Presence of alternative / additional supply arrangement warning notice(s) at or near equipment, where required: (N/A)		5.3 Condition of insulation of live parts: (✓)		6.2 Cables correctly supported throughout their length: (LIM)	
3. Automatic disconnection of supply		5.4 Adequacy / security of barriers: (✓)		6.3 Condition of insulation of live parts: (✓)	
3.1 Main earthing and bonding arrangements		5.5 Condition of enclosure(s) in terms of IP rating: (✓)		6.4 Non-sheathed cables protected by enclosures in conduit, ducting or trunking: (✓)	
a) Presence and condition of distributor's earthing arrangement: (✓)		5.6 Condition of enclosure(s) in terms of fire rating: (✓)		6.5 Suitability of containment systems for continued use (including flexible conduit): (✓)	
b) Presence and condition of earth electrode arrangement, if present: (N/A)		5.7 Enclosure not damaged / deteriorated so as to impair safety: (✓)		6.6 Cables correctly terminated in enclosures (indicate extent of sampling in PART 7 of report): (✓)	
c) Adequacy of earthing conductor size: (✓)		5.8 Presence and effectiveness of obstacles: (✓)		6.7 Indication of SPD(s) continued functionality confirmed: (✓)	
d) Adequacy of earthing conductor connections: (✓)		5.9 Presence of main switch(es), linked where required: (✓)		6.8 Adequacy of AFDD(s), where specified: (N/A)	
e) Accessibility of earthing conductor connections: (✓)		5.10 Operation of main switch(es) (functional check): (✓)		6.9 Confirmation that conductor connections, including connections to busbars are correctly located in terminals and are tight and secure: (✓)	
f) Adequacy of main protective bonding conductor size(s): (✓)		5.11 Correct identification of circuit protective devices: (✓)		6.10 Examination of cables for signs of unacceptable thermal and mechanical damage / deterioration: (✓)	
g) Adequacy of main protective bonding conductor connections: (✓)		5.12 Adequacy of protective devices for prospective fault current: (✓)		6.11 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation: (✓)	
h) Accessibility of main protective bonding connections: (✓)		5.13 RCD(s) provided for fault protection – includes RCBOs: (✓)		6.12 Adequacy of protective devices; type and rated current for fault protection: (✓)	
i) Accessibility and condition of other protective bonding connections: (✓)		5.14 RCD(s) provided for additional protection – includes RCBOs: (✓)		6.13 Presence and adequacy of circuit protective conductors: (✓)	
j) Provision of earthing / bonding labels at all appropriate locations: (✓)		5.15 RCD(s) provided for protection against fire – includes RCBOs: (✓)		6.14 Co-ordination between conductors and overload protective devices: (✓)	
3.2 FELV		5.16 Manual operation of circuit-breakers and RCDs to prove disconnection: (✓)		6.15 Cable installation methods / practices appropriate to the type and nature of installation and external influences: (✓)	
a) Source providing at least simple separation: (N/A)		5.17 Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check): (✓)		6.16 Cables where exposed to direct sunlight, of a suitable type or adequately protected against solar radiation: (✓)	
b) Plugs, socket-outlets and the like not interchangeable with those of other systems within the premises: (N/A)		5.18 Presence of RCD six-monthly retest notice at or near equipment, where required: (✓)		6.17 Cables adequately protected against damage and abrasion: (✓)	
		5.19 Presence of diagrams, charts or schedules at or near equipment, where required: (✓)			
		5.20 Presence of non-standard (mixed) cable colour warning notices at or near equipment, where required: (N/A)			
		5.21 Presence of next inspection recommendation label: (✓)			
		5.22 All other required labelling provided: (✓)			
		5.23 Compatibility of protective device(s), base(s) and other components: (✓)			

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately – CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

Original (to the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 10 : SCHEDULE OF ITEMS INSPECTED

- 6.18 Provision of additional protection by an RCD not exceeding 30 mA
 - a) For all socket-outlets with a rated current not exceeding 32 A, unless exempt:
 - b) Supplies for mobile equipment with a rated current not exceeding 32 A for use outdoors:
 - c) For cables concealed in walls / partitions at a depth of less than 50 mm:
 - d) For cables concealed in walls / partitions containing metal parts regardless of depth:
 - e) Circuits supplying luminaires within domestic (household) premises:
- Note:** Older installations designed prior to BS 7671: 2018 may not have been provided with RCDs for additional protection.
- 6.19 Provision of fire barriers, sealing arrangements and protection against thermal effects:
- 6.20 Band II cables segregated / separated from Band I cables:
- 6.21 Cables segregated / separated from non-electrical services:
- 6.22 Termination of cables at enclosures *(indicate extent of sampling in PART 7 of report)*
 - a) Connections under no undue strain:
 - b) No basic insulation of a conductor, visible outside an enclosure:
 - c) Connections of live conductors adequately enclosed:
 - d) Adequacy of connection at point of entry to enclosure:
- 6.23 Temperature rating of cable insulation adequate:
- 6.24 Condition of accessories including socket-outlets, switches and joint boxes satisfactory:
- 6.25 Suitability of accessories for external influences:

- 6.26 Single-pole switching or protective devices in line conductors only:
 - 6.27 Adequacy of connections, including cpcs, within accessories and to fixed and stationary equipment:
- ### 7. Isolation and switching
- 7.1 Isolators
 - a) Presence and condition of appropriate devices:
 - b) Acceptable location (local / remote):
 - c) Capable of being secured in the OFF position:
 - d) Correct operation verified:
 - e) Clearly identified by position and / or durable markings:
 - f) Warning label posted in situations where live parts cannot be isolated by the operation of a single device:
 - 7.2 Switching off for mechanical maintenance
 - a) Presence and condition of appropriate devices:
 - b) Acceptable location:
 - c) Capable of being secured in the OFF position:
 - d) Correct operation verified:
 - e) Clearly identified by position and / or durable marking(s):
 - 7.3 Emergency switching off / stopping
 - a) Presence and condition of appropriate devices: N/A
 - b) Readily accessible for operation where danger might occur: N/A
 - c) Correct operation verified: N/A
 - 7.4 Functional switching
 - a) Presence and condition of appropriate devices:
 - b) Correct operation (functionality) verified:

- ### 8. Current-using equipment (permanently connected)
- 8.1 Condition of equipment in terms of IP rating:
 - 8.2 Equipment does not constitute a fire hazard:
 - 8.3 Enclosure not damaged / deteriorated so as to impair safety:
 - 8.4 Suitability for the environment and external influences:
 - 8.5 Security of fixing:
 - 8.6 Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire:
- List number and location of luminaires inspected on a separate page: Page No. (N/A)
- 8.7 Recessed luminaires (e.g. downlighters)
 - a) Correct type of lamps fitted:
 - b) Installed to minimise build-up of heat:
 - c) No signs of overheating to surrounding building fabric:
 - d) No signs of overheating to conductors / terminations:

- ### 9. List all special installations or locations covered by this report
- N/A (N/A)
- (.....)
- (.....)
- (.....)
- (.....)

Indicate if the relevant requirements of Part 7 are satisfied and append results of inspection on a separate numbered page.

SCHEDULE OF ITEMS INSPECTED BY

Name (capitals): CHRIS SPARKS

Signature: Date: 17/08/2020

PART 11 : SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections	Schedule of Circuit Details and Test Results for the installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 9. above)	Continuation sheets
Page No(s): <input type="checkbox"/> 4 & 5 <input type="checkbox"/>	Page No(s): <input type="checkbox"/> 6, 7-29 <input type="checkbox"/>	Page No(s): <input type="checkbox"/> None <input type="checkbox"/>	Page No(s): <input type="checkbox"/> None <input type="checkbox"/>	Page No(s): <input type="checkbox"/> None <input type="checkbox"/>

The pages identified are an essential part of this report (see Regulation 653.2).

All fields must be completed. Enter either, as appropriate: '✓' if Acceptable condition; 'N/A' if Not applicable; 'LIM' if a Limitation exists; or Code appropriately – CODE 'C1', 'C2', 'C3' or 'FI' (codes to be recorded in PART 6, with additional comments (where appropriate) on attached numbered sheets)

Original (to the person ordering the work)

ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

PART 12 : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS Circuits/equipment vulnerable to damage when testing **N/A**

Circuit number	Circuit description	CODES for Type of wiring		Type of wiring (See Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD		Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons								
		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit				(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(I) other - state: N/A	Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Ring final circuits only (measured end to end)				All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)	RCD (✓)	AFDD (✓)		
							(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂							(✓)																	
							(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂							(✓)																	
1L1	Plant Room	G	C	1	25	10	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
1L2	Plant Room	G	C	1	25	10	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
1L3	Plant Room	G	C	1	25	10	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
2L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A										
2L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A										
2L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A										
3L1	Fire Alarm	D	B	1	6	6	0.4	60947-2	MCCB16	18	N/A	N/A	N/A	N/A	N/A	0.03	N/A	N/A	>299	500	✓	0.08	N/A	N/A	N/A										
3L2	Comms Supply	G	C	1	6	6	0.4	60947-2	MCCB32	18	N/A	N/A	N/A	N/A	N/A	0.07	N/A	N/A	>299	500	✓	0.13	N/A	N/A	N/A										
3L3	External Lights DB	D	B	1	10	10	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	0.03	N/A	N/A	>299	500	✓	0.08	N/A	N/A	N/A										
4L1	Ground Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
4L2	Ground Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
4L3	Ground Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.10	N/A	N/A	N/A										
5L1	First Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										
5L2	First Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										
5L3	First Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										
6L1	Second Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										
6L2	Second Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										
6L3	Second Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A										

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: DB Main Panel
Location of DB: Mains Electrical Cupboard

TESTED BY Name (capitals): CHRIS SPARKS
Signature: *Chris Sparks*
Position: QS
Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (N/A) Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A) Rating: (N/A) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (N/A) Phase sequence confirmed (where appropriate): (N/A) Z_s (N/A) Ω I_{pf} (N/A) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂								
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)				R ₂	(MΩ)
7L1	Third Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A	
7L2	Third Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A	
7L3	Third Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.04	N/A	N/A	>299	500	✓	0.09	N/A	N/A	N/A	
8L1	Fourth Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8L2	Fourth Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8L3	Fourth Floor DB	G	E	1	25	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
9L1	Aov DB	D	B	1	6	6	5	60947-2	MCCB16	18	N/A	N/A	N/A	N/A	N/A	0.03	N/A	N/A	>299	500	✓	0.08	N/A	N/A	N/A	
9L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
9L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
10L1	Lift 1	G	E	1	10	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	
10L2	Lift 1	G	E	1	10	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	
10L3	Lift 1	G	E	1	10	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	
11L1	Laundry DB	G	F	1	16	Arm	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.14	N/A	N/A	>299	500	✓	0.20	N/A	N/A	N/A	
11L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
11L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
12L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

DISTRIBUTION BOARD (DB) DETAILS DB designation: DB Main Panel **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Mains Electrical Cupboard Signature: [Signature] Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (N/A) Nominal voltage: (N/A) V No. of phases: (N/A)
 Overcurrent protection device for the distribution circuit Type: (BS EN N/A) Rating: (N/A) A
 Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms
 Characteristics at this DB Confirmation of supply polarity: (N/A) Phase sequence confirmed (where appropriate): (N/A) Z_s (N/A) Ω I_{pf} (N/A) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101847990) Continuity: (N/A)
 Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
 Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons								
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)							
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂															
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)				R ₂	(MΩ)	(MΩ)	(V)	(ms)	(✓)	(✓)		
13L1	Lift 2	G	E	1	16	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13L2	Lift 2	G	E	1	16	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
13L3	Lift 2	G	E	1	16	Arm	5	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	LIM	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
14L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
14L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	60947-2	MCCB40	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
15L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
16L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17L1	Surge Protection	D	B	1	16	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.01	N/A	N/A	>299	500	✓	0.07	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17L2	Surge Protection	D	B	1	16	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.01	N/A	N/A	>299	500	✓	0.07	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
17L3	Surge Protection	D	B	1	16	16	5	60947-2	MCCB63	18	N/A	N/A	N/A	N/A	N/A	0.01	N/A	N/A	>299	500	✓	0.07	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
18L1	Meter	D	B	1	2.5	N/A	5	60947-2	MCCB25	18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>DB Main Panel</u> Location of DB: <u>Mains Electrical Cupboard</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>14/08/2020</u>
---	--	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (N/A) Nominal voltage: (N/A) V No. of phases: (N/A)

Overcurrent protection device for the distribution circuit Type: (BS EN N/A) Rating: (N/A) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (N/A) Phase sequence confirmed (where appropriate): (N/A) Z_s (N/A) Ω I_{pf} (N/A) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS
Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing **N/A**

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in non-metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: N/A																												
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted Z_s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z_s (Ω)	RCD operating time (ms)	Test buttons													
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)												
														(Line) r_1	(Neutral) r_n	(cpc) r_2	$(R_1 + R_2)$	R_2																				
1L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L1	Swing Frees	A	B	1	2.5	1.5	0.4	60898	B	10	6	N/A	4.37	N/A	N/A	N/A	0.10	N/A	N/A	N/A	>299	500	✓	0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
3L2	Appliances 1-3	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.71	0.71	0.90	0.40	N/A	N/A	N/A	>299	500	✓	0.52	7.41	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A	
3L3	Appliances 4-6	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.80	0.80	0.96	0.44	N/A	N/A	N/A	>299	500	✓	0.54	7.4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
4L1	Hand Dryer/Dis Alarm	A	B	2	2.5	1.5	0.4	61009	B	16	6	30	2.73	N/A	N/A	N/A	0.48	N/A	N/A	N/A	>299	500	✓	0.59	8.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
4L2	Appliances 11-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.97	0.97	1.29	0.56	N/A	N/A	N/A	>299	500	✓	0.65	8.4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
4L3	Appliances 14-17	A	B	16	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.84	0.84	1.31	0.53	N/A	N/A	N/A	>299	500	✓	0.40	8.99	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
5L1	TV/Dado Sockets	A	B	10	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.10	1.10	0.30	0.35	N/A	N/A	N/A	>299	500	✓	0.76	7.4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
5L2	Kitchen Appliances	A	B	6	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.74	0.74	1.30	0.51	N/A	N/A	N/A	>299	500	✓	0.52	8.5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
5L3	Office Sockets	A	B	N/A	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.61	0.61	1.07	0.42	N/A	N/A	N/A	>299	500	✓	0.52	8.6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
6L1	Corridor Sockets	A	B	3	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	0.81	0.42	N/A	N/A	N/A	>299	500	✓	0.32	8.8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
6L2	Dining/Kitchen Sockets	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.10	1.10	1.18	0.57	N/A	N/A	N/A	>299	500	✓	0.37	7.8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	N/A
6L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS DB designation: Ground Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Mains Electrical Room Signature: [Signature] Date: 12/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (DB Main Panel - 4L1) Nominal voltage: (400) V No. of phases: (3)
 Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A
 Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) $I_{\Delta n}$ (N/A) mA Operating time (N/A) ms
 Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.1) Ω I_{pf} (3.2) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101847990) Continuity: (N/A)
 Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
 Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in non-metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂								
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)				R ₂	(MΩ)
7L1	Bin Store Power	A	B	1	2.5	1.5	0.4	61009	B	20	6	30	2.19	N/A	N/A	N/A	0.78	N/A	N/A	>299	500	✓	0.88	8	✓	N/A
7L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
7L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L3	TV Room Sockets	A	B	6	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.51	0.51	0.80	0.32	N/A	N/A	>299	500	✓	0.32	7.41	✓	N/A
9L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10L2	Comms Room General Sockets	A	B	4	2.5	1.5	0.4	61009	B	20	6	30	2.19	N/A	N/A	N/A	0.21	N/A	N/A	>299	500	✓	0.30	8.1	✓	N/A
10L3	Pods	A	B	4	2.5	1.5	0.4	61009	B	20	6	30	2.19	N/A	N/A	N/A	0.61	N/A	N/A	>299	500	✓	0.70	7.4	✓	N/A
11L1	Appliances 7-10	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.99	0.99	1.40	0.59	N/A	N/A	>299	500	✓	0.99	9.01	✓	N/A
11L2	Sockets 1-3	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.75	0.75	0.96	0.42	N/A	N/A	>299	500	✓	0.40	8.69	✓	N/A
11L3	Sockets 4-6	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.83	0.83	1.23	0.51	N/A	N/A	>299	500	✓	0.47	8.8	✓	N/A
12L1	Sockets 7-10	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.36	1.36	1.96	0.83	N/A	N/A	>299	500	✓	0.56	8.8	✓	N/A
12L2	Sockets 11-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.06	1.06	1.63	0.67	N/A	N/A	>299	500	✓	0.47	7.8	✓	N/A
12L3	Sockets 14-17	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.10	1.10	1.26	0.59	N/A	N/A	>299	500	✓	0.41	8.59	✓	N/A

DISTRIBUTION BOARD (DB) DETAILS DB designation: Ground Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Mains Electrical Room Signature: Date: 12/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 4L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.1) Ω I_{pf} (3.2) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate) Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons												
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)											
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂																			
																		(MΩ)	(MΩ)	(V)																	
1L1	Spare																																				
1L2	Spare																																				
1L3	Spare																																				
2L1	Spare																																				
2L2	Spare																																				
2L3	Spare																																				
3L1	Spare																																				
3L2	Spare																																				
3L3	Spare																																				
4L1	Spare																																				
4L2	Spare																																				
4L3	Lights Outside Electrical Room	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37																								
5L1	Lights 7-10	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								
5L2	Lights 1-3	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								
5L3	Lights 4-6	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								
6L1	Corridor Lights	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								
6L2	Lights 11-13	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								
6L3	Lights 14-17	A	B		1.5	1	0.4	61009	B	10	6	30	4.37																								

DISTRIBUTION BOARD (DB) DETAILS DB designation: Ground Floor Lighting **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Main Electrical Room Signature: [Signature] Date: 13/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 4L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.1) Ω I_{pf} (3.2) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																	
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max. disconnection time (BS 7671) (s)	Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)			Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons				
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)				Live / Earth (MΩ)	Test voltage DC (V)	RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
7L1	Lights Electrical Room	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				0.20			>299	250	✓	0.30	8.4	✓	N/A	
7L2	Lights Kitchen	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				1.92			>299	250	✓	2.01	7.8	✓	N/A	
7L3	Lights Amenity Area	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				1.24			>299	250	✓	1.33	7.9	✓	N/A	
8L1	Lights Seating Pods	A	B	4	1.5	1	0.4	61009	B	10	6	30	4.37				1.41			>299	250	✓	1.52	8.4	✓	N/A	
8L2	Spare																										
8L3	Lights Office	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				0.86			>299	250	✓	0.96	8.5	✓	N/A	

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>Ground Floor Lighting</u> Location of DB: <u>Main Electrical Room</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>13/08/2020</u>
---	---	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 4L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.1) Ω I_{pf} (3.2) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS
Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing **N/A**

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in non-metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: **N/A**

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)				R ₂	(MΩ)	(MΩ)
1L1	Sockets Studios 6-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.74	0.74	0.49	0.30	N/A	N/A	>299	500	✓	0.39	8.4	✓	N/A	
1L2	Sockets Studios 1-5	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.77	0.77	0.56	0.33	N/A	N/A	>299	500	✓	0.45	7.3	✓	N/A	
1L3	Sockets Studios 10-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.79	0.79	0.36	0.30	N/A	N/A	>299	500	✓	0.44	8.61	✓	N/A	
2L1	Sockets Studios 18-21	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.01	1.01	1.10	0.52	N/A	N/A	>299	500	✓	0.41	8.69	✓	N/A	
2L2	Sockets Studios 14-17	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.71	0.71	0.52	0.30	N/A	N/A	>299	500	✓	0.28	7.91	✓	N/A	
2L3	Sockets Studios 22-26	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.16	1.16	1.30	0.61	N/A	N/A	>299	500	✓	0.48	9.1	✓	N/A	
3L1	Sockets Studios 27-29	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	1.23	2.13	N/A	N/A	>299	500	✓	0.40	7.2	✓	N/A	
3L2	Sockets Studios 30-33	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	0.80	0.42	N/A	N/A	>299	500	✓	0.43	7.5	✓	N/A	
3L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L1	Appliances 6-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.46	0.46	0.49	0.23	N/A	N/A	>299	500	✓	0.25	7	✓	N/A	
4L2	Appliances 1-5	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.71	0.71	0.60	0.32	N/A	N/A	>299	500	✓	0.33	7.5	✓	N/A	
4L3	Appliances 10-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.55	0.55	0.47	0.25	N/A	N/A	>299	500	✓	0.26	9.12	✓	N/A	
5L1	Appliances 18-21	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.74	0.74	0.78	0.38	N/A	N/A	>299	500	✓	0.40	9.39	✓	N/A	
5L2	Appliances 14-17	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.55	0.55	0.62	0.29	N/A	N/A	>299	500	✓	0.36	7.4	✓	N/A	
5L3	Appliances 22-26	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.94	0.94	1.11	0.51	N/A	N/A	>299	500	✓	0.32	7.6	✓	N/A	
6L1	Appliances 27-29	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.81	0.81	1.18	0.49	N/A	N/A	>299	500	✓	0.48	8.4	✓	N/A	
6L2	Appliances 30-33	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.62	0.62	0.68	0.32	N/A	N/A	>299	500	✓	0.32	7.4	✓	N/A	
6L3	Swing Frees	A	B	6	2.5	1.5	0.4	61009	B	6	6	30	7.28	N/A	N/A	N/A	0.12	N/A	N/A	>299	500	✓	0.20	8.5	✓	N/A	

DISTRIBUTION BOARD (DB) DETAILS DB designation: First Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
(to be completed in every case) Location of DB: First Floor Riser Signature: [Signature] Date: 18/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Supply to DB is from: (DB Main Panel - 5L1) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms
Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
Multi-function: (101847990) Continuity: (N/A)
Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956 ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS


Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)						Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)			Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
7L1	Corridor Sockets	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.46	0.46	0.56	0.25	N/A	N/A	>299	500	✓	0.29	8.5	✓	N/A	
7L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8L1	Corridor Sockets	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.97	0.97	0.94	0.47	N/A	N/A	>299	500	✓	0.32	8.7	✓	N/A	
8L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
8L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

DISTRIBUTION BOARD (DB) DETAILS DB designation: First Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: First Floor Riser Signature:  Date: 18/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 5L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																	
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
1L1	Lights Studios 6-9	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.57			>299	250	✓	1.64	8.4	✓	N/A	
1L2	Lights Studios 1-5	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.64			>299	250	✓	1.75	8.5	✓	N/A	
1L3	Lights Studios 10-13	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.55			>299	250	✓	1.65	8.4	✓	N/A	
2L1	Lights Studio 18-21	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.51			>299	250	✓	1.60	8.6	✓	N/A	
2L2	Lights Studio 14-17	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.45			>299	250	✓	1.56	9.1	✓	N/A	
2L3	Lights Studio 22-26	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				2.16			>299	250	✓	2.25	9	✓	N/A	
3L1	Lights Studio 27-29	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.68			>299	250	✓	1.77	8.6	✓	N/A	
3L2	Lights Studio 30-33	A	B	12	1.5	1	0.4	61009	B	10	6	30	4.37				1.58			>299	250	✓	1.61	7.8	✓	N/A	
3L3	Lights Corridor	A	B	8	1.5	1	0.4	61009	B	10	6	30	4.37				3.10			>299	250	✓	1.92	8.4	✓	N/A	
4L1	Spare																										
4L2	Spare																										
4L3	Lights Corridor	A	B	10	1.5	1	0.4	61009	B	10	6	30	4.37				3.80			>299	250	✓	3.30	8.6	✓	N/A	

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>First Floor Lighting</u> Location of DB: <u>First Floor Riser</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>14/08/2020</u>
---	---	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 5L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS
Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS
(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted Z_s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z_s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r_1	(Neutral) r_n	(cpc) r_2	$(R_1 + R_2)$	R_2								
1L1	Sockets Studio 1-5	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.84	0.84	0.83	0.41			>299	500	✓	0.42	8.6	✓	N/A
1L2	Sockets Studio 6-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.77	0.77	1.23	0.50			>299	500	✓	0.39	8.1	✓	N/A
1L3	Sockets Studio 10-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	0.77	0.41			>299	500	✓	0.42	8.5	✓	N/A
2L1	Sockets Studio 19-22	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.96	0.96	1.09	0.51			>299	500	✓	0.40	7.8	✓	N/A
2L2	Sockets Corridor	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.42	0.42	0.55	0.23			>299	500	✓	0.26	8.3	✓	N/A
2L3	Sockets Studio 23-27	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.46	1.46	1.67	0.78			>299	500	✓	0.59	8.3	✓	N/A
3L1	Sockets Studio 28-31	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.86	0.86	0.70	0.39			>299	500	✓	0.38	7.29	✓	N/A
3L2	Sockets Studio 14-18	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.74	0.74	0.52	0.31			>299	500	✓	0.35	7.5	✓	N/A
3L3	Spare																									
4L1	Appliances 1-5	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.76	0.76	0.50	0.31			>299	500	✓	0.31	7.9	✓	N/A
4L2	Appliances 6-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.48	0.48	0.42	0.22			>299	500	✓	0.28	8.4	✓	N/A
4L3	Appliances 10-13	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.58	0.58	0.55	0.28			>299	500	✓	0.24	8.4	✓	N/A
5L1	Appliances 19-22	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.67	0.67	0.83	0.37			>299	500	✓	0.30	9.1	✓	N/A
5L2	Appliances 14-18	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.61	0.61	0.52	0.28			>299	500	✓	0.30	8.6	✓	N/A
5L3	Appliances 23-27	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.00	1.00	0.96	0.49			>299	500	✓	0.44	7.2	✓	N/A
6L1	Appliances 28-31	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.65	0.65	0.56	0.30			>299	500	✓	0.26	7.2	✓	N/A
6L2	Sockets Corridor	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	0.71	0.40			>299	500	✓	0.30	8.6	✓	N/A
6L3	Swing Frees	A	B	5	2.5	1.5	0.4	61009	B	6	6	30	7.28				0.16			>299	500	✓	0.24	8.5	✓	N/A

DISTRIBUTION BOARD (DB) DETAILS DB designation: Second Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Second Floor Riser Signature: [Signature] Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (DB Main Panel - 6L1) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) $I_{\Delta n}$ (N/A) mA Operating time (N/A) ms
Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101847990) Continuity: (N/A)
 Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
 Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa		Max. disconnection time (BS 7671)	Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity <input checked="" type="checkbox"/>	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons						
					Live (mm ²)	cpc (mm ²)		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD <input checked="" type="checkbox"/>	AFDD <input checked="" type="checkbox"/>					
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂													
7L1	Spare																														
7L2	Spare																														
7L3	Spare																														
8L1	Spare																														
8L2	Spare																														
8L3	Spare																														

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)
 DB designation: Second Floor Power
 Location of DB: Second Floor Riser
TESTED BY Name (capitals): CHRIS SPARKS
 Signature: Position: QS
 Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
 Supply to DB is from: (DB Main Panel - 6L1)
 Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn}: (N/A) mA Operating time (N/A) ms
Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s: (0.09) Ω I_{pf}: (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
 Multi-function: (101847990) Continuity: (N/A)
 Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
 Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations


XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
																									(ms)	(✓)	(✓)
1L1	Lights Studios 1-5	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				2.01			>299	250	✓	2.10	8.4	✓	N/A	
1L2	Lights Studios 6-9	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.96			>299	250	✓	2.05	8.9	✓	N/A	
1L3	Lights Studios 10-13	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.12			>299	250	✓	1.20	9.6	✓	N/A	
2L1	Lights Studios 19-22	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.97			>299	250	✓	2.04	9.3	✓	N/A	
2L2	Lights Studios 14-18	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.94			>299	250	✓	2.03	8.5	✓	N/A	
2L3	Lights Studios 23-27	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.79			>299	250	✓	1.89	8.3	✓	N/A	
3L1	Lights Studios 28-31	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37				1.81			>299	250	✓	1.90	8.4	✓	N/A	
3L2	Lights Corridor Long	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				1.56			>299	250	✓	1.64	9.4	✓	N/A	
3L3	Spare																										
4L1	Spare																										
4L2	Lights Corridor Short	A	B		1.5	1	0.4	61009	B	10	6	30	4.37				3.73			>299	250	✓	3.81	8.6	✓	N/A	
4L3	Spare																										

DISTRIBUTION BOARD (DB) DETAILS DB designation: Second Floor Lighting **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Second Floor Riser Signature:  Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 6L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)

CONTINUATION SHEET:
ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS
Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS
(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing **N/A**

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in non-metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: **N/A**

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
																									(ms)	(ms)	(ms)
1L1	Sockets Studios 9-11	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.55	0.55	0.89	0.36	N/A	N/A	>299	500	✓	0.33	7.7	✓	N/A	
1L2	Sockets Studios 1-4	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.71	0.71	0.45	0.29	N/A	N/A	>299	500	✓	0.34	7.7	✓	N/A	
1L3	Sockets Studios 5-8	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.89	0.89	1.29	0.54	N/A	N/A	>299	500	✓	0.51	7.6	✓	N/A	
2L1	Sockets Studios 12-15	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.90	0.90	0.74	0.41	N/A	N/A	>299	500	✓	0.38	8.3	✓	N/A	
2L2	Sockets Studios 16-19	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.86	0.86	0.80	0.42	N/A	N/A	>299	500	✓	0.36	8.9	✓	N/A	
2L3	Sockets Studios 20-23	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.29	1.29	1.16	0.61	N/A	N/A	>299	500	✓	0.50	8.6	✓	N/A	
3L1	Sockets Studios 24-27	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.89	0.89	1.16	0.51	N/A	N/A	>299	500	✓	0.46	8.7	✓	N/A	
3L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L1	Appliances 9-11	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.39	0.39	0.33	0.18	N/A	N/A	>299	500	✓	0.20	7.3	✓	N/A	
4L2	Appliances 1-4	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.52	0.52	0.35	0.21	N/A	N/A	>299	500	✓	0.25	8.8	✓	N/A	
4L3	Appliances 5-8	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.70	0.70	0.42	0.28	N/A	N/A	>299	500	✓	0.24	8.5	✓	N/A	
5L1	Appliances 12-15	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.58	0.58	0.58	0.29	N/A	N/A	>299	500	✓	0.32	8.3	✓	N/A	
5L2	Appliances 16-19	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.54	0.54	0.64	0.29	N/A	N/A	>299	500	✓	0.28	8.8	✓	N/A	
5L3	Appliances 20-23	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.93	0.93	0.96	0.47	N/A	N/A	>299	500	✓	0.34	8.9	✓	N/A	
6L1	Appliances 24-27	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.46	0.46	0.45	0.22	N/A	N/A	>299	500	✓	0.20	7.3	✓	N/A	
6L2	Sockets Corridor	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.39	0.39	0.55	0.24	N/A	N/A	>299	500	✓	0.25	8.5	✓	N/A	
6L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS DB designation: Third Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
(to be completed in every case) Location of DB: Third Floor Riser Signature: [Signature] Date: 17/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Supply to DB is from: (DB Main Panel - 7L1) Nominal voltage: (400) V No. of phases: (3)
Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms
Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)
Multi-function: (101847990) Continuity: (N/A)
Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
Earth electrode resistance: (N/A) RCD: (N/A)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)						Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons											
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)			Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)										
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂																			
																										(ms)	(ms)	(ms)	(ms)								
7L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7L2	Sockets Corridor	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.67	0.67	0.58	0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
7L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L1	Swing Frees	A	B	5	2.5	1.5	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	0.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: Third Floor Power **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS

Location of DB: Third Floor Riser Signature: [Signature] Date: 17/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 7L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)						Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)			Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂				(MΩ)	(MΩ)
1L1	Lights Studio 9-11	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.12	N/A	N/A	>299	250	✓	0.79	8.2	✓	N/A	
1L2	Lights Studio 1-4	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.00	N/A	N/A	>299	250	✓	1.65	8.5	✓	N/A	
1L3	Lights Studio 5-8	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.90	N/A	N/A	>299	250	✓	1.40	8.1	✓	N/A	
2L1	Lights Studio 12-15	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.06	N/A	N/A	>299	250	✓	1.76	8.8	✓	N/A	
2L2	Lights Studio 16-19	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.82	N/A	N/A	>299	250	✓	1.48	9	✓	N/A	
2L3	Lights Studio 20-23	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.53	N/A	N/A	>299	250	✓	2.36	8.4	✓	N/A	
3L1	Lights Studio 24-27	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.15	N/A	N/A	>299	250	✓	1.70	8.7	✓	N/A	
3L2	Lights Corridor	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.70	N/A	N/A	>299	250	✓	1.50	9	✓	N/A	
3L3	Lights Corridor	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	3.12	N/A	N/A	>299	250	✓	2.43	9	✓	N/A	
4L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS DB designation: Third Floor Lighting **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Third Floor Riser Signature: Date: 17/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 7L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.09) Ω I_{pf} (2.7) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS


Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS
(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring			(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted Z_s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity	Max. measured earth fault loop impedance, Z_s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm^2)	cpc (mm^2)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (M Ω)	Live / Earth (M Ω)	Test voltage DC (V)				RCD (\checkmark)	AFDD (\checkmark)	
														(Line) r_1	(Neutral) r_n	(cpc) r_2	$(R_1 + R_2)$	R_2									
1L1	Sockets Studios 15-18	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.74	0.74	0.61	0.33			>299	500	\checkmark	0.44	8.5	\checkmark		
1L2	Sockets Studios 5-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.93	0.93	0.68	0.41			>299	500	\checkmark	0.46	8.5	\checkmark		
1L3	Sockets Studios 1-4	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.80	0.80	0.46	0.31			>299	500	\checkmark	0.25	8.6	\checkmark		
2L1	Sockets Studios 19-22	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.77	0.77	0.83	0.40			>299	500	\checkmark	0.38	8.5	\checkmark		
2L2	Sockets Studios 10-14	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	1.0	1.0	0.59	0.39			>299	500	\checkmark	0.39	7.8	\checkmark		
2L3	Spare																									N/A	
3L1	Appliances 15-18	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.68	0.68	0.97	0.39			>299	500	\checkmark	0.33	7.7	\checkmark		
3L2	Appliances 5-9	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.65	0.65	0.52	0.30			>299	500	\checkmark	0.30	9.6	\checkmark		
3L3	Appliances 1-4	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.62	0.62	0.47	0.27			>299	500	\checkmark	0.25	9.4	\checkmark		
4L1	Appliances 19-22	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.46	0.46	0.43	0.23			>299	500	\checkmark	0.27	7.4	\checkmark		
4L2	Appliances 10-14	A	B	12	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.81	0.81	0.55	0.34			>299	500	\checkmark	0.24	8.6	\checkmark		
4L3	Corridor Sockets	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.58	0.58	0.47	0.26			>299	500	\checkmark	0.26	8.7	\checkmark		
5L1	Swing Frees	A	B	5	2.5	1.5	0.4	60898	B	10	6	N/A	4.37				0.11			>299	500	\checkmark	0.18	8.4	\checkmark		
5L2	Spare																									N/A	
5L3	Sockets Corridor	A	B	4	2.5	1.5	0.4	61009	B	32	6	30	1.37	0.36	0.36	0.28	0.18			>299	500	\checkmark	0.19	8.7	\checkmark		
6L1	Spare																										
6L2	Spare																										
6L3	Spare																										

DISTRIBUTION BOARD (DB) DETAILS DB designation: Fourth Floor Power
 (to be completed in every case) Location of DB: Fourth Floor Riser

TESTED BY Name (capitals): CHRIS SPARKS Position: QS
 Signature:  Date: 18/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 8L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) $I_{\Delta n}$ (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (\checkmark) Phase sequence confirmed (where appropriate): (\checkmark) Z_s (0.1) Ω I_{pf} (2.5) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																	
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
1L1	Lights Studios 15-18	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.94	N/A	N/A	>299	250	✓	1.60	8.4	✓	N/A	
1L2	Lights Studios 5-9	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.12	N/A	N/A	>299	250	✓	1.90	9	✓	N/A	
1L3	Lights Studios 1-4	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.90	N/A	N/A	>299	250	✓	1.55	8.7	✓	N/A	
2L1	Lights Studios 19-22	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.92	N/A	N/A	>299	250	✓	1.58	8.4	✓	N/A	
2L2	Lights Studios 10-14	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.35	N/A	N/A	>299	250	✓	2.05	8.8	✓	N/A	
2L3	Lights Corridor	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	1.60	N/A	N/A	>299	250	✓	1.40	8.9	✓	N/A	
3L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3L3	Lights Corridor	A	B	24	1.5	1	0.4	61009	B	10	6	30	4.37	N/A	N/A	N/A	2.30	N/A	N/A	>299	250	✓	2.15	8.6	✓	N/A	
4L1	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L2	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4L3	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>Fourth Floor Lighting</u> Location of DB: <u>Fourth Floor Riser</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>17/08/2020</u>
---	---	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 8L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.1) Ω I_{pf} (2.5) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																	
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)	
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂									
1L1	BMS Panel	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.10			>299	250	✓	0.20				
1L2	BMS Panel	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.10			>299	250	✓	0.20				
1L3	BMS Panel	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.10			>299	250	✓	0.20				
2L1	Booster Pump	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.16			>299	250	✓	0.26				
2L2	Booster Pump	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.16			>299	250	✓	0.26				
2L3	Booster Pump	G	C	1	6	6	0.4	60898	C	40	10	N/A	0.55				0.16			>299	250	✓	0.26				
3L1	Spare																										
3L2	Spare																										
3L3	Water Softener	G	C	1	1.5	1.5	0.4	60898	C	10	10	N/A	2.19				0.55			>299	250	✓	0.65				
4L1	AC Unit Outside	G	C	1	6	6	0.4	60898	C	20	10	N/A	1.09				0.25			>299	250	✓	0.35				
4L2	AC Unit Outside	G	C	1	6	6	0.4	60898	C	20	10	N/A	1.09				0.25			>299	250	✓	0.35				
4L3	AC Unit Outside	G	C	1	6	6	0.4	60898	C	20	10	N/A	1.09				0.25			>299	250	✓	0.35				
5L1	AC Unit Outside	G	C	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19				0.35			>299	250	✓	0.45				
5L2	Spare																										
5L3	AC Ring Main	A	B	6	2.5	1.5	0.4	60898	C	32	10	30	0.68	1.09	1.09	0.58	0.41			>299	500	✓	0.45				
6L1	Spare																										
6L2	Spare																										
6L3	Spare																										

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>Plant Room DB</u> Location of DB: <u>Plant Room</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>17/08/2020</u>
---	---	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 1L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): () Z_s (0.1) Ω I_{pf} (2.1) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons				
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)			
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂											
																		(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)				R ₂	(MΩ)	(MΩ)	(V)	(ms)
7L1	CHP 1	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.34			>299	250	✓	0.44						
7L2	CHP 1	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.34			>299	250	✓	0.44						
7L3	CHP 1	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.34			>299	250	✓	0.44						
8L1	CHP 2	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.31			>299	250	✓	0.42						
8L2	CHP 2	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.31			>299	250	✓	0.42						
8L3	CHP 2	G	C	1	6	6	0.4	60898	C	32	10	N/A	0.68				0.31			>299	250	✓	0.42						
9L1	Socket Next to DB	A	B	1	2.5	1.5	0.4	61009	B	16	6	30	2.73				0.05			>299	250	✓	0.12	8.49					
9L2	Lights	A	B	3	1.5	1	0.4	61009	B	10	6	30	4.37				0.41			>299	250	✓	0.51	8.4					
9L3	Cat 5 Pump	G	C	1	2.5	2.5	0.4	60898	B	10	6	N/A	4.37				0.54			>299	250	✓	0.64						
10L1	Spare																												
10L2	Spare																												
10L3	Spare																												
11L1	Spare																												
11L2	Spare																												
11L3	Spare																												
12L1	Mobus Metre Supply	D	B	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19				LIM							0.15					
12L2	Mobus Metre Supply	D	B	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19				LIM							0.15					
12L3	Mobus Metre Supply	D	B	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19				LIM							0.15					

DISTRIBUTION BOARD (DB) DETAILS DB designation: Plant Room DB **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS
 (to be completed in every case) Location of DB: Plant Room Signature: *Chris Sparks* Date: 17/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 1L1) Nominal voltage: (400) V No. of phases: (3)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: (✓) Phase sequence confirmed (where appropriate): (✓) Z_s (0.1) Ω I_{pf} (2.1) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

CONTINUATION SHEET:

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: FP200

Table with columns for Circuit number, Circuit description, Type of wiring, Protective device, RCD, Circuit impedances, Insulation resistance, etc. Row 1: L1, Fire Alarm, O, B, 1, 16, 6, 0.4, 1361, I, 15, 16.5, N/A, 3.12, N/A, N/A, N/A, 0.33, N/A, N/A, >299, 250, Polarity checked, 0.40, N/A, N/A, N/A.

DISTRIBUTION BOARD (DB) DETAILS DB designation: Fire Alarm DB (to be completed in every case) Location of DB: Main Electrical Room TESTED BY Name (capitals): CHRIS SPARKS Position: QS Signature: [Signature] Date: 18/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION Supply to DB is from: (DB Main Panel - 3L1) Nominal voltage: (230) V No. of phases: (1) Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (16) A Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) Operating time (N/A) ms Characteristics at this DB Confirmation of supply polarity: (checked) Phase sequence confirmed (where appropriate): (N/A) Zs (0.08) Ohms Ipf (3.4) kA

TEST INSTRUMENTS (enter serial number against each instrument used) Multi-function: (101847990) Continuity: (N/A) Insulation resistance: (N/A) Earth fault loop impedance: (N/A) Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)

CONTINUATION SHEET:

ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

(Delete as appropriate)

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring	(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: N/A																			
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Max. disconnection time (BS 7671) (s)	Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted Z_s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity <input checked="" type="checkbox"/>	Max. measured earth fault loop impedance, Z_s (Ω)	RCD operating time (ms)	Test buttons		
					Live (mm ²)	cpc (mm ²)	BS (EN)		Type	Rating (A)	Short-circuit capacity (kA)	Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (M Ω)	Live / Earth (M Ω)	Test voltage DC (V)	RCD <input checked="" type="checkbox"/>	AFDD <input checked="" type="checkbox"/>							
												(Line) r_1			(Neutral) r_n	(cpc) r_2						(R ₁ + R ₂)				R ₂		
L1	AOV Spurs	A	B	5	2.5	1.5	0.4	1361	I	15	16.5	N/A	3.12	N/A	N/A	N/A	0.45	N/A	N/A	>299	250	<input checked="" type="checkbox"/>	0.54	N/A	N/A	N/A	N/A	

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)

DB designation: Aov DB **TESTED BY** Name (capitals): CHRIS SPARKS Position: QS

Location of DB: Main Electrical Room Signature: [Signature] Date: 18/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 9L1) Nominal voltage: (230) V No. of phases: (1)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (16) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) $I_{\Delta n}$ (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): (N/A) Z_s (0.08) Ω I_{pf} (3.3) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)

Insulation resistance: (N/A) Earth fault loop impedance: (N/A)

Earth electrode resistance: (N/A) RCD: (N/A)

Original (to the person ordering the work)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956

ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring

- (A) Thermoplastic insulated / sheathed cables (B) Thermoplastic cables in metallic conduit (C) Thermoplastic cables in non-metallic conduit (D) Thermoplastic cables in metallic trunking (E) Thermoplastic cables in non-metallic trunking (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Mineral-insulated cables (O) other - state: N/A

Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, $I_{\Delta n}$ (mA)	Maximum permitted Z_s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z_s (Ω)	RCD operating time (ms)	Test buttons	
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)
														(Line) r_1	(Neutral) r_n	(cpc) r_2	($R_1 + R_2$)	R_2								
L1	Outside Lights	A	B	8	1.5	1	0.4	61009	B	6	6	30	7.28	N/A	N/A	N/A	N/A	N/A	N/A	>299	250	✓	4.40	9.4	✓	N/A
L2	Not in Use	A	B	N/A	1.5	1	0.4	61009	B	6	6	30	7.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
L3	Photo Cell	A	B	1	1.5	1	0.4	60898	B	6	6	N/A	7.28	N/A	N/A	N/A	0.17	N/A	N/A	>299	250	✓	0.26	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS
(to be completed in every case)

DB designation: External Lighting
Location of DB: Main Electrical Room

TESTED BY

Name (capitals): CHRIS SPARKS

Signature:

Position: QS

Date: 14/08/2020

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 3L3) Nominal voltage: (230) V No. of phases: (1)
Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (40) A
Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) $I_{\Delta n}$ (N/A) mA Operating time (N/A) ms
Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): (N/A) Z_s (0.08) Ω I_{pf} (3) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (101847990) Continuity: (N/A)
 Insulation resistance: (N/A) Earth fault loop impedance: (N/A)
 Earth electrode resistance: (N/A) RCD: (N/A)



This continuation sheet is not valid if the serial number is not the same as the corresponding certificate or report.

21773956 ISN18C

CONTINUATION SHEET: ELECTRICAL INSTALLATION CERTIFICATES & ELECTRICAL INSTALLATION CONDITION REPORTS

Issued in accordance with BS 7671: 2018 – Requirements for Electrical Installations

XXX / IPN : SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuits/equipment vulnerable to damage when testing N/A

CODES for Type of wiring		(A) Thermoplastic insulated / sheathed cables	(B) Thermoplastic cables in metallic conduit	(C) Thermoplastic cables in non-metallic conduit	(D) Thermoplastic cables in metallic trunking	(E) Thermoplastic cables in non-metallic trunking	(F) Thermoplastic / SWA cables	(G) Thermosetting / SWA cables	(H) Mineral-insulated cables	(O) other - state: <u>N/A</u>																		
Circuit number	Circuit description	Type of wiring (see Codes)	Reference Method (BS 7671)	Number of points served	Circuit conductor csa			Protective device				RCD Operating current, I _{Δn} (mA)	Maximum permitted Z _s for installed protective device* (Ω)	Circuit impedances (Ω)					Insulation resistance			Polarity (✓)	Max. measured earth fault loop impedance, Z _s (Ω)	RCD operating time (ms)	Test buttons			
					Live (mm ²)	cpc (mm ²)	Max. disconnection time (BS 7671) (s)	BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)			Ring final circuits only (measured end to end)			All circuits (complete at least one column)		Live / Live (MΩ)	Live / Earth (MΩ)	Test voltage DC (V)				RCD (✓)	AFDD (✓)		
														(Line) r ₁	(Neutral) r _n	(cpc) r ₂	(R ₁ + R ₂)	R ₂										
L1	Dryer 1	E	B	1	4	4	0.4	60898	C	25	10	N/A	0.87	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A
L2	Dryer 2	E	B	1	4	4	0.4	60898	C	25	10	N/A	0.87	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A
L3	Socket	E	B	1	2.5	2.5	0.4	60898	C	16	10	N/A	1.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A
L4	L/View & CVA	A	B	2	2.5	1.5	0.4	60898	C	10	10	N/A	2.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A
L5	Washer 3	E	B	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A
L6	Washer 4	E	B	1	2.5	2.5	0.4	60898	C	10	10	N/A	2.19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	LIM	N/A	N/A	N/A

DISTRIBUTION BOARD (DB) DETAILS (to be completed in every case)	DB designation: <u>Laundry DB</u> Location of DB: <u>Laundry Room</u>	TESTED BY Name (capitals): <u>CHRIS SPARKS</u> Signature:	Position: <u>QS</u> Date: <u>17/08/2020</u>
---	--	---	--

TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: (DB Main Panel - 11L1) Nominal voltage: (230) V No. of phases: (1)

Overcurrent protection device for the distribution circuit Type: (BS EN 60947-2) Rating: (63) A

Associated RCD (if any) Type: (BS EN N/A) No. of poles: (N/A) I_{Δn} (N/A) mA Operating time (N/A) ms

Characteristics at this DB Confirmation of supply polarity: () Phase sequence confirmed (where appropriate): (NA) Z_s (0.2) Ω I_{pf} (1.2) kA

TEST INSTRUMENTS (enter serial number against each instrument used)

Multi-function: (<u>101847990</u>)	Continuity: (<u>N/A</u>)
Insulation resistance: (<u>N/A</u>)	Earth fault loop impedance: (<u>N/A</u>)
Earth electrode resistance: (<u>N/A</u>)	RCD: (<u>N/A</u>)

Original (to the person ordering the work)

NOTES FOR RECIPIENT

THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, *BS 7671: 2018 – Requirements for Electrical Installations*.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 6), together with any items for which improvement is recommended.

If you were the person ordering this report, but not the user of the installation, you should pass this report, or a full copy of it including these notes, the schedules and additional pages (if any), immediately to the user.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested every six months. For safety reasons it is important that this instruction is followed.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC* recommends that you engage the services of an NICEIC Approved Contractor for the inspection.

The recommended date by which the next inspection should be carried out is stated in PART 5 of this report. There should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

Only an NICEIC Approved Contractor or Conforming Body is authorised to issue this NICEIC Electrical Installation Condition Report. You should have received the report marked 'Original' and the Approved Contractor should have retained the report marked 'Duplicate'.

This report form is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least six numbered pages. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. For installations having more than one distribution board or more circuits than can be recorded on PART 12, one or more additional *Schedules of Circuit Details and Test Results* should form part of the report. The report is invalid if any of the schedules identified in PART 10 are missing. The report has a printed serial number, which is traceable to the Contractor to which it was supplied.

PART 7 (Details and limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 7. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 6. Where one or more observations have been made in PART 6, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) **the safety of those using the installation is at risk**. Wherever practicable, items classified as (C1) should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) **the safety of those using the installation may be at risk**, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 8 *Supply Characteristics and Earthing Arrangements*, and the *Schedules of Circuit Details and Test Results* (PART 12) compiled accordingly.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 10), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the Approved Contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or cost).

** NICEIC is operated by Certsure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).*

For further information about electrical safety and how NICEIC
can help you, visit www.niceic.com

GUIDANCE FOR RECIPIENTS ON THE CLASSIFICATION CODES

Only one Classification code should be given for each recorded Observation

Classification code C1 (Danger present)

Where an observation has been given a Classification code C1, the safety of those using the installation is at risk and immediate remedial action is required.

The person responsible for the maintenance of the installation is advised to take action without delay to remedy the observed deficiency in the installation, or to take other appropriate action (such as switching off and isolating the affected part(s) of the installation) to remove the danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

NICEIC makes available 'Electrical Danger Notification' forms to enable inspectors to record, and then to communicate to the person ordering the report, any dangerous condition discovered.

Classification code C2 (Potentially dangerous)

Classification code C2 indicates that, whilst those using the installation may not be at immediate risk, urgent remedial action is required to remove potential danger. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

It is important to note that the recommendation given at PART 5 of this report (Next Inspection) for the maximum interval until the next inspection is conditional upon all items which have been given a Classification code C1 and code C2 being remedied immediately and as a matter of urgency, respectively.

It would not be reasonable for the inspector to indicate that the installation is in a satisfactory condition if any observation in this report has been given a code C1 or code C2 classification.

Classification code C3 (Improvement recommended)

Where an observation has been given a Classification code C3, the inspection and/or testing has revealed a non-compliance with the current safety standard which, whilst not presenting immediate or potential danger, would result in a significant safety improvement if remedied. Careful consideration should be given to the safety benefits of improving these aspects of the installation. The NICEIC Approved Contractor issuing this report will be able to provide further advice.

Code FI (Further investigation required without delay)

It should usually be possible for the inspector to attribute a Classification code to each observation without indicating a need for further investigation.

However, where 'FI' has been entered against an observation the inspector considers that further investigation of that observation is likely to reveal danger or potential danger that, due to the agreed extent or limitations of the inspection and/or testing, could not be fully identified at the time.

It would not be appropriate for the inspector to indicate that the installation is in a satisfactory condition if there is reasonable doubt as to whether danger or potential danger exists. Consequently, where the inspector has indicated 'Further investigation required without delay' (FI) the overall assessment of the installation (PART 3) should be marked as 'Unsatisfactory'.

If the inspector has indicated that an observation requires further investigation without delay, the person ordering this report is advised to arrange for the NICEIC Approved Contractor issuing the report (or another skilled person or persons competent in such work) to undertake further examination of that aspect of the installation as a matter of urgency, to determine whether or not danger or potential danger exists.

Further information

Further information on the application of Classification codes, primarily aimed at inspectors but of possible interest to persons ordering condition reports, can be found in Electrical Safety First's Best Practice Guide No 4 *Electrical installation condition reporting: Classification Codes for domestic and similar electrical installations*. The guide can be viewed or downloaded free of charge from www.electricalsafetyfirst.org.uk

For further information about electrical safety and how NICEIC can help you, visit www.niceic.com