

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003661

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
Electrical installation in apartment M01 on Mezz level

Extent of the installation covered by this certificate
All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
None

Details of permitted exception (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners.	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova Way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003661

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		


Reviewed By	PD CLAPHAM	Reviewed By	P.D. Clapham
Reviewed By Date	18/08/2023	Signature	

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Gareth Davies		

Reviewed By	R Bird	Reviewed By	
Reviewed By Date	21-08-23	Signature	

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	400/230	v	Nominal frequency, f _n ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	88-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003661

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Location Electrode resistance to earth Ω

Means of Earthing
 Distributors facility Installation Earth Electrode
 Maximum Demand (load) 80 Amps KVA

Main Protective Conductors
 Earthing Conductor Material Copper csa 16 mm² Continuity Verified Connection Verified
 Protective Bonding Conductor Material N/A csa N/A mm² Continuity Verified Connection Verified

Main Supply Conductor Material Copper csa 16 mm² (connection / continuity) (✓) or Value

Main Switch Location Utility cupboard in Apartment

Fuse/device rating or setting Switch A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A
 If RCD main switch: Rated residual operating current I_{Δn} N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Gareth Davies
 Date: 18/08/2023

Signature: Gareth Davies

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 9334000003661

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s): T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Location Utility cupboard in apartment	Distribution protective device for the distribution circuit: No. of phases 1 BS(EN) 60947-3 Type N/A Rating 100 A	Supply to distribution board is from: Main Incomer
Designation Apartment M01	No. of ways 16	Nominal voltage 230 V RCD BS(EN) 61008 Type A Rating 30 IΔn mA	

SCHEDULE OF CIRCUIT DETAILS

Circuit No and Line	Circuit designation	Type of wiring	Pole method =	No. of points served	Circuit conductors csa (mm ²)			Overcurrent protective devices			BS 7671 Max permitted Zs Other Other B	RCD				
					L/N	CNC	Maximum disconnection time BS 7671 (s)	BS EN Number	Type No	Rating (A)		BS EN Number	Type No	Rating (A)		
1/S	Bed/Store sockets	O	103	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Kitchen Sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Living room sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance grid switches	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	1/10	4	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE															
7/S	RCD MODULE															
8/S	Hob	O	1/10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	1/10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	
10/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
11/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	61009	N/A	N/A	
12/S	SPARE															
13/S	RCD MODULE															
14/S	RCD MODULE															
15/S	Towel Radiator	O	1/10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
16/S	Lighting	O	1/10	25	1.5	1.0	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	
17/S	SPARE															
18/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

* SPD Type: Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results.

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

FT/EIC 9334000003661

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:

No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN)
 Z_{in} Ω Operating at I_{dn} mA
 I_n kA No. of poles Time delay (if applicable)

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	MVA Measured Z_e (V)	RCD testing MFRCDs I _{dn} mA	Manual test button operation			
	Ring final circuits only			R1 or R2	Test voltage V	L1, L/N M(O)	L2, N/E M(O)				RCD	RCD		
	r1	m	r2										R1 + R2	R2
1/S	0.40	0.40	0.20	✓	0.18	N/A	500	>500	>500	✓	0.29	37.9	✓	✓
2/S	0.30	0.33	0.41	✓	0.15	N/A	500	>500	>500	✓	0.28	37.5	✓	✓
3/S	0.38	0.38	0.33	✓	0.22	N/A	500	>500	>500	✓	0.23	38.0	✓	✓
4/S	0.11	0.11	0.18	✓	0.38	N/A	500	>500	>500	✓	0.32	38.0	✓	✓
5/S	N/A	N/A	N/A	N/A	0.54	N/A	250	>500	>500	✓	0.59	28.5	✓	N/A
6/S	N/A	N/A	N/A	N/A						N/A		58.9	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		58.9	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.09	N/A	500	>500	>500	✓	0.27	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.17	N/A	500	>500	>500	✓	0.37	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.35	N/A	500	>500	>500	✓	0.34	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.50	N/A	500	>500	>500	✓	0.53	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
13/S	N/A	N/A	N/A	N/A						N/A		59.0	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		59.0	✓	N/A
15/S	N/A	N/A	N/A	N/A	0.31	N/A	500	>500	>500	✓	0.34	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A	1.12	N/A	250	>500	>500	✓	1.22	N/A	N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing: To
 Date(s) live testing: To

Test instrument serial number(s):

Loop impedance: Insulation resistance: Continuity: RCD: E/Electrode:

Tested by: Name (capital letters) Signature:
 Position: Date:

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003662

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation

Electrical installation in apartment M02 on mezz level

Extent of the installation covered by this certificate

All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

None

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann partners	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra nova way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By			
Reviewed By Date	18/08/2023	Signature			

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003662

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		
Reviewed By	PD CLAPHAM	Reviewed By	P.D. Clapham		
Reviewed By Date	18/08/2023				

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	
		Signature	Gareth Davies		
Reviewed By	R.B.D.	Reviewed By			
Reviewed By Date	21-08-23				

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	V	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _s ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	88-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003662

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of installation at the Origin

Means of Earthing

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility Installation Earth Electrode
 Location Electrode resistance to earth Ω Maximum Demand (load) 80 Amps KVA

Main Protective Conductors

Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper 16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	N/A N/A mm ²	Continuity Verified <input type="checkbox"/>	Connection Verified <input type="checkbox"/>

Main Supply Conductor Material csa mm² (connection / continuity) (✓) or Value (✓) or Value
 Main Switch Location Utility cupboard in Apartment

Water installation Ω To structural steel Ω
 Gas installation pipes Ω To lightning protection Ω
 Oil installation pipes Ω Other Ω

Fuse/device rating or setting A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A
 If RCD main switch: Rated residual operating current I Δn mA Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Gareth Davies
 Date: 18/08/2023

Signature Gareth Davies

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003662

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671: 2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details Type(s) ¹	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit	Supply to distribution board is from: <input type="text" value="Main incomer"/>
Location	<input type="text" value="Utility cupboard in apartment"/>	No. of phases	<input type="text" value="1"/> BS(EN) <input type="text" value="60947-3"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="100"/> A
Designation	<input type="text" value="Apartment M02"/>	Nominal voltage	<input type="text" value="230"/> V RCD BS(EN) <input type="text" value="61008"/> Type <input type="text" value="A"/> Rating <input type="text" value="30"/> mA
No. of ways	<input type="text" value="22"/>		

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Rcd method [†]	No. of points served	Circuit conductors csa (mm ²)		Maximum disconnection time (s) (BS 7671)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Icu (kA) or Ics (kA) [‡]	RCD			
					L/N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	U _{pn} (V)	Rating (A)
1/S	Store sockets	O	0/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
2/S	Kitchen sockets	O	0/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
3/S	Bedroom sockets	O	0/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
4/S	Bedroom/Living room sockets	O	0/10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
5/S	Kitchen appliance grid switch	O	0/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
6/S	Fire Alarm	O	0/10	6	1.5	1.0	0.4	61009 RCD/RCBO	B	6	0.4	7.28	61009	A	30	N/A
7/S	RCD MODULE														30	
8/S	RCD MODULE														30	
9/S	Hob	O	0/10	2	6	2.5	0.4	60898 MCB	C	32	0.4	0.68	N/A	N/A	N/A	N/A
10/S	Immersion/ ASHP	O	0/10	1	2.5	1.5	0.4	60898 MCB	C	20	0.4	1.09	N/A	N/A	N/A	N/A
11/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
12/S	Towel Radiator	O	0/10	2	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
13/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
14/S	RCD MODULE														30	
15/S	RCD MODULE														30	
16/S	Towel Radiator	O	0/10	2	2.5	1.5	0.4	60898 MCB	C	16	0.4	1.37	N/A	N/A	N/A	N/A
17/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
18/S	Lighting	O	0/10	34	1.5	1.0	0.4	60898 MCB	C	6	0.4	3.64	N/A	N/A	N/A	N/A
19/S	SPARE															
20/S	SPARE															
21/S	SPARE															
22/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

[†] SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
[‡] Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022)
[§] See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
[¶] Where the maximum permitted earth fault loop impedance value stated in Max Za column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the charge to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003662

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lambly Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:

No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD: Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN)
 Z_{in} Ω Operating at I_{dn} mA
 I_n kA No. of poles Time delay (if applicable)

TEST RESULTS

Circuit No and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z_e (Ω)	RCD testing All RCDs with ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2	Test voltage V	LL, LN M(Ω)	L-E, N-E M(Ω)				RCD	AFDD		
	r1	m	r2										$R1 + R2$	R2
1/S	0.16	0.16	0.13	✓	0.12	N/A	500	>500	>500	✓	0.18	38.0	✓	✓
2/S	0.22	0.20	0.20	✓	0.12	N/A	500	>500	>500	✓	0.19	37.9	✓	✓
3/S	0.28	0.28	0.19	✓	0.14	N/A	500	>500	>500	✓	0.23	37.9	✓	✓
4/S	0.56	0.55	0.39	✓	0.27	N/A	500	>500	>500	✓	0.37	38.0	✓	✓
5/S	0.11	0.10	0.19	✓	0.23	N/A	500	>500	>500	✓	0.30	38.1	✓	✓
6/S	N/A	N/A	N/A	N/A	0.64	N/A	500	>500	>500	✓	0.68	28.3	✓	✓
7/S	N/A	N/A	N/A	N/A						N/A		60.4	✓	N/A
8/S	N/A	N/A	N/A	N/A						N/A		60.4	✓	N/A
9/S	N/A	N/A	N/A	N/A	0.11	N/A	500	>500	>500	✓	0.31	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.05	N/A	500	>500	>500	✓	0.35		N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.10	N/A	500	>500	>500	✓	0.39		N/A	N/A
12/S	N/A	N/A	N/A	N/A	0.13	N/A	500	>500	>500	✓	0.36		N/A	N/A
13/S	N/A	N/A	N/A	N/A	0.14	N/A	500	>500	>500	✓	0.38		N/A	N/A
14/S				N/A						N/A		60.6	✓	N/A
15/S	N/A	N/A	N/A	N/A						N/A		60.6	✓	N/A
16/S	N/A	N/A	N/A	N/A	0.18	N/A	500	>500	>500	✓	0.40		N/A	N/A
17/S	N/A	N/A	N/A	N/A	0.28	N/A	500	>500	>500	✓	0.39		N/A	N/A
18/S	N/A	N/A	N/A	N/A	1.44	N/A	500	>500	>500	✓	1.13		N/A	N/A
19/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
20/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
21/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
22/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing: To
 Date(s) live testing: To

Test instrument serial number(s):

Loop impedance: Insulation resistance: Continuity: RCD: E/Electrode:

Tested by: Name (capital letters) Signature:
 Position: Date:

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003663

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671: 2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
Electrical installation in apartment M03 on Mezz level

Extent of the installation covered by this certificate
All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
none

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners.	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova Way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				
Next inspection	I the designer recommend that this installation is further inspected after an interval of not more than 10 years				

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003663

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022.

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		


Reviewed By	PD CLAPHAM	Reviewed By Signature	P.D. Clapham
Reviewed By Date	18/08/2023		

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022.

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Gareth Davies		

Reviewed By	R.B.D.	Reviewed By Signature	
Reviewed By Date	21-08-23		

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SNE
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	66-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003663

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Means of Earthing

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), pipe etc)

Location Electrode resistance to earth Ω

Maximum Demand (load) 80 Amps KVA

Distributors facility Installation Earth Electrode

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16	mm ²	Continuity Verified <input checked="" type="checkbox"/> Ω
Protective Bonding Conductor	N/A	N/A	mm ²	Continuity Verified <input type="checkbox"/> N/A Ω
				Connection Verified <input checked="" type="checkbox"/> Ω
				Connection Verified <input type="checkbox"/> N/A Ω

Main Supply Conductor	Material	csa	(✓) or Value	(✓) or Value
	Copper	16	mm ²	Water installation <input type="checkbox"/> N/A Ω
				To structural steel <input type="checkbox"/> N/A Ω
				Gas installation pipes <input type="checkbox"/> N/A Ω
				To lightning protection <input type="checkbox"/> N/A Ω
				Oil installation pipes <input type="checkbox"/> N/A Ω
				Other <input type="checkbox"/> N/A Ω

Main Switch Location Utility cupboard in Apartment.

Fuse/device rating or setting Switch A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A

If RCD main switch: Rated residual operating current I_{Δn} N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Gareth Davies

Signature Gareth Davies

Date: 18/08/2023

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003663

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case

SPD Details Type(s):¹ T1 T2 T3 N/A

Location: Utility cupboard in apartment

Designation: Apartment M03

No. of ways: 18

Complete only if the distribution board is not connected directly to the origin of the installation

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Main Incomer

No. of phases: 1 BS(EN) 60947-3 Type N/A Rating 100 A

Nominal voltage 230 V RCD BS(EN) 61008 Type A Rating 30 IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Label	Circuit designation	Type of wiring	RCD method ²	No. of points served	Circuit conductors (mm ²)			Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max permitted Z _s Other Other § (%)	RCD			
					L/N	CPC	Min. conductor size BS 7671 (S)	BS EN Number	Type No	Rating (A)			BS EN Number	Type No	On (mA)	Rating (A)
1/S	Bed/Store sockets	O	1/10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Kitchen Sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Living room sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance grid switches	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	1/10	4	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE														30	
7/S	RCD MODULE														30	
8/S	Hob	O	1/10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	1/10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	
10/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
11/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
12/S	SPARE															
13/S	RCD MODULE														30	
14/S	RCD MODULE														30	
15/S	Towel Radiator	O	1/10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
16/S	Lighting	O	1/10	25	1.5	1.0	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	
17/S	SPARE															
18/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

¹ SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
² Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022)
³ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
[§] Where the maximum permitted earth fault loop impedance value stated in Max Z_s column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003663

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (JET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street . Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:
 No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD: Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN)
 Z_{in} Ω Operating at I_{dn} rms
 I_n kA No. of poles Time delay (if applicable)

TEST RESULTS

Circuit No. and Label	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. measured Z_{in} (Ω)	RCD testing At RCD origin ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2	Test voltage V	LL, LN M(Ω)	LE, NE M(Ω)				RCD (✓)	OT/IO (✓)		
	r1	m	r2										✓	R1 + R2
1/S	0.35	0.35	0.24	✓	0.20	N/A	500	>500	>500	✓	0.16	38.0	✓	✓
2/S	0.35	0.35	0.26	✓	0.15	N/A	500	>500	>500	✓	0.16	38.0	✓	✓
3/S	0.21	0.21	0.16	✓	0.12	N/A	500	>500	>500	✓	0.17	38.0	✓	✓
4/S	0.14	0.14	0.23	✓	0.20	N/A	500	>500	>500	✓	0.22	28.2	✓	✓
5/S	N/A	N/A	N/A	N/A	0.47	N/A	500	>500	>500	✓	0.33	28.5	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		91	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		91	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.08	N/A	500	>500	>500	✓	0.26	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.08	N/A	500	>500	>500	✓	0.35	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.22	N/A	500	>500	>500	✓	0.37	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.14	N/A	500	>500	>500	✓	0.34	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
13/S	N/A	N/A	N/A	N/A						N/A		88.5	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		88.5	✓	N/A
15/S	N/A	N/A	N/A	N/A	0.11	N/A	500	>500	>500	✓	0.32	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A	1.10	N/A	500	>500	>500	✓	1.27	N/A	N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing: To
 Date(s) live testing: To

Test instrument serial number(s)

Loop impedance Insulation resistance Continuity RCD E/Electrode

Tested by Name (capital letters) Signature
 Position Date

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003664

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
Electrical installation in apartment M04 on mezz level

Extent of the installation covered by this certificate
All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
none

Details of permitted exception (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann partners	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra nova way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003664

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Declaration for Construction

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate

Company	Whitehead Building Services Ltd	Position	Project Manager	
Inspector Name	Paul Clapham	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No. 11922
		Signature	Paul Clapham	
Reviewed By		Reviewed By Signature		
Reviewed By Date	18/08/2023			

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate

Company	Whitehead Building Services Ltd	Position	Approved Electrician	
Inspector Name	Gareth Davies	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No. 11922
		Signature	Gareth Davies	
Reviewed By		Reviewed By Signature		
Reviewed By Date	18/08/2023			

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _s ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	BS-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003664

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of Installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) **Means of Earthing**
 Location Electrode resistance to earth Ω **Distributors facility** **Installation Earth Electrode**
 Maximum Demand (load) 50 Amps KVA

Main Protective Conductors **Material** **csa** (✓) or Value (✓) or Value

Earthing Conductor Copper 16 mm² Continuity Verified Ω Connection Verified Ω

Protective Bonding Conductor N/A N/A mm² Continuity Verified N/A Ω Connection Verified N/A Ω

Main Supply Conductor **Material** **csa** (connection / continuity) (✓) or Value (✓) or Value

Copper 16 mm² Water installation N/A Ω To structural steel N/A Ω

Main Switch Location Utility cupboard in Apartment. Gas installation pipes N/A Ω To lightning protection N/A Ω

Oil installation pipes N/A Ω Other N/A Ω

Fuse/device rating or setting Switch A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A

If RCD main switch: Rated residual operating current I_{Δn} N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Gareth Davies
 Date: 18/08/2023

Signature: Gareth Davies

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003664

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit	Supply to distribution board is from: <input type="text" value="Main Incomer"/>
Location	Utility cupboard in apartment	No. of phases	1 <input type="checkbox"/> 2 <input type="checkbox"/> 3 <input type="checkbox"/> BS(EN) 60947-3 Type <input type="text" value="N/A"/> Rating <input type="text" value="100"/> A
Designation	Apartment M04	Nominal voltage	230 <input type="checkbox"/> V RCD BS(EN) 61008 Type <input type="text" value="A"/> Rating <input type="text" value="30"/> IΔn mA
No. of ways	22		

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductors csa (mm²)			Overcurrent protective devices			Disrupting capacity (kA)	BS 7671 Max permitted Z _s (Ω) Other (Ω)	RCD			
					L/N	CPC	Maximum disconnection time (s) (BS 7671)	BS EN Number	Type No	Rating (A)			BS EN Number	Type No	Rating (A)	
1/S	Store/Study sockets	O	0/10	7	2.5	1.5	0.4	61008 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
2/S	Kitchen sockets	O	0/10	4	2.5	1.5	0.4	61008 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
3/S	Hall sockets	O	0/10	4	2.5	1.5	0.4	61008 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
4/S	Bedroom/Living room sockets	O	0/10	6	2.5	1.5	0.4	61008 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
5/S	Kitchen appliance grid switch	O	0/10	5	2.5	1.5	0.4	61008 RCD/RCBO	B	32	0.4	1.37	61009	A	30	N/A
6/S	Fire Alarm	O	0/10	7	1.5	1.0	0.4	61008 RCD/RCBO	B	6	0.4	7.25	61009	A	30	N/A
7/S	RCD MODULE														30	
8/S	RCD MODULE														30	
9/S	Hob	O	0/10	2	6	2.5	0.4	60898 MCB	C	32	0.4	0.68	N/A	N/A	N/A	N/A
10/S	Immersion/ ASHP	O	0/10	1	2.5	1.5	0.4	60898 MCB	C	20	0.4	1.09	N/A	N/A	N/A	N/A
11/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
12/S	Towel Radiator	O	0/10	2	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
13/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
14/S	RCD MODULE														30	
15/S	RCD MODULE														30	
16/S	Towel Radiator	O	0/10	2	2.5	1.5	0.4	60898 MCB	C	16	0.4	1.37	N/A	N/A	N/A	N/A
17/S	Heater	O	0/10	1	2.5	1.5	0.4	60898 MCB	B	16	0.4	2.73	N/A	N/A	N/A	N/A
18/S	Heater	O	0/10	40	1.5	1.0	0.4	60898 MCB	C	6	0.4	3.64	N/A	N/A	N/A	N/A
19/S	Lighting	O	0/10	40	1.5	1.0	0.4	60898 MCB	C	6	0.4	3.64	N/A	N/A	N/A	N/A
20/S	SPARE															
21/S	SPARE															
22/S	SPARE															

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/GWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MB** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
 § Where the maximum permitted earth fault loop impedance value stated in Max Z_s column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results.

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003664

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:
 No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD: Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EH)
 Z_{in} : Ω Operating at I_{dn}: ms
 I_{tr} : kA No. of poles: Time delay (if applicable):

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Priority	Max. measured Z_{in} (Ω)	RCD testing All RCDs idn ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2	Test voltage V	L-L, L-N M(Ω)	L-E, N-E M(Ω)				RCD	RCD		
	r1	m	r2										<input checked="" type="checkbox"/>	R1 + R2
1/S	0.39	0.41	0.16	<input checked="" type="checkbox"/>	0.08	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.36	38.1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
2/S	0.20	0.20	0.26	<input checked="" type="checkbox"/>	0.14	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.24	28.0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
3/S	0.32	0.34	0.28	<input checked="" type="checkbox"/>	0.24	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.25	37.9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
4/S	0.48	0.48	0.40	<input checked="" type="checkbox"/>	0.28	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.32	38.0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5/S	0.09	0.10	0.15	<input checked="" type="checkbox"/>	0.26	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.29	38.2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
6/S	N/A	N/A	N/A	N/A	0.86	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.79	28.1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
7/S	N/A	N/A	N/A	N/A						N/A		57.9	<input checked="" type="checkbox"/>	N/A
8/S	N/A	N/A	N/A	N/A						N/A		57.9	<input checked="" type="checkbox"/>	N/A
9/S	N/A	N/A	N/A	N/A	0.10	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.25	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.09	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.52		N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.14	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.55		N/A	N/A
12/S	N/A	N/A	N/A	N/A	0.23	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.68		N/A	N/A
13/S	N/A	N/A	N/A	N/A	0.21	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.62		N/A	N/A
14/S	N/A	N/A	N/A	N/A						N/A		52.3	<input checked="" type="checkbox"/>	N/A
15/S	N/A	N/A	N/A	N/A						N/A		52.3	<input checked="" type="checkbox"/>	N/A
16/S	N/A	N/A	N/A	N/A	0.23	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.59		N/A	N/A
17/S	N/A	N/A	N/A	N/A	0.24	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.57		N/A	N/A
18/S	N/A	N/A	N/A	N/A	0.27	N/A	500	>500	>500	<input checked="" type="checkbox"/>	0.58		N/A	N/A
19/S	N/A	N/A	N/A	N/A	1.71	N/A	500	>500	>500	<input checked="" type="checkbox"/>	1.42	N/A	N/A	N/A
20/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
21/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
22/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:

Date(s) dead testing: To
 Date(s) live testing: To

Test instrument serial number(s):

Loop impedance: Insulation resistance: Continuity: RCD: E/Electrode:

Tested by: Name (capital letters) Signature:
 Position: Date:

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003665

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises: Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is: New Addition Alteration Records Available: Yes No RCD Risk assessment attached

Description of the installation

Electrical installation in apartment M05 on Mezz level

Extent of the installation covered by this certificate

All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

None

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners.	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova Way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection: I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003665

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 : 2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager	
Inspector Name	Paul Clapham	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No	NICEIC-11922	Branch No 11922
		Signature	Paul Clapham	

Reviewed By	P.D. CLAPHAM	Reviewed By Signature	P.D. Clapham
Reviewed By Date	18/08/2023		

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician	
Inspector Name	Gareth Davies	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No	NICEIC-11922	Branch No
		Signature	Gareth Davies	

Reviewed By	R Bin	Reviewed By Signature	
Reviewed By Date	21-08-23		

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	3	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U ₀ ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device (EN)	BS-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003665

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc)

Location Electrode resistance to earth Ω

Main Protective Conductors

	Material	csa	(\checkmark) or Value	(\checkmark) or Value
Earthing Conductor	Copper	16	mm ²	Continuity Verified <input checked="" type="checkbox"/> <input type="text"/> Ω Connection Verified <input checked="" type="checkbox"/> <input type="text"/> Ω
Protective Bonding Conductor	N/A	N/A	mm ²	Continuity Verified <input type="checkbox"/> N/A Ω Connection Verified <input type="checkbox"/> N/A Ω

Main Supply Conductor Material csa mm²

Main Switch Location

Fuse/device rating or setting A Voltage rating V BS(EN) No. of Poles Current Rating A

If RCD main switch: Rated residual operating current I_{Δn} mA Rated time delay ms Measured operating trip time ms

Means of Earthing

Distributors facility Installation Earth Electrode

Maximum Demand (load) Amps KVA

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under fabric, in roof spaces and generally within the fabric of the building or underground may not have been inspected

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		<input checked="" type="checkbox"/>	Indicates the inspection is not applicable to a particular item		<input type="checkbox"/>
1.0	Condition of consumer's intake equipment (visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and Final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	<input checked="" type="checkbox"/>	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	<input checked="" type="checkbox"/>	10.0	Current-using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic Protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measure other than ADS	<input checked="" type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input checked="" type="checkbox"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	<input checked="" type="checkbox"/>
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	<input checked="" type="checkbox"/>

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name:

Signature:

Date:

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003665

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case

SPD Details: Type(s)* T1 T2 T3 N/A

Location: Utility cupboard in apartment

Designation: Apartment M05

No. of ways: 18

Complete only if the distribution board is not connected directly to the origin of the installation

Overcurrent protective device for the distribution circuit: Supply to distribution board is from Main incomer

No. of phases: 1 BS(EN) 60947-3 Type: N/A Rating: 100 A

Nominal voltage: 230 V RCD BS(EN) 61008 Type: A Rating: 30 Idn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Pole method †	No. of points served	Circuit conductors csa (mm²)			Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other ‡	RCD			
					L / N	CPC	Maximum impedance from BS 7671 (Ω)	BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Idn (mA)	Rating (A)
1/S	Bed/Store sockets	O	1/10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Kitchen Sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Living room sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance grid switches	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	1/10	3	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE															
7/S	RCD MODULE															
8/S	Hob	O	1/10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	1/10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	
10/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
11/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
12/S	SPARE															
13/S	RCD MODULE															
14/S	RCD MODULE															
15/S	Towel Radiator	O	1/10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
16/S	Lighting	O	1/10	20	1.5	1.0	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	
17/S	SPARE															
18/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/XPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.

† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)

‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.

§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate call for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003665

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lambly Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location: Utility cupboard in apartment
Designation: Apartment M05

No. of ways: 18 Supply polarity confirmed Phase sequence confirmed
No. of phases: 1 SPO Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN) 61008
Z_s: 0.14 Operating at I_{Δn}: ms
I_n: 1.85 kA No. of poles: 2 Time delay (if applicable): N/A

TEST RESULTS

Circuit No. and Label	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z _s (Ω)	RCD testing All RCDs in ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2	Test voltage V	LL, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFCI (✓)		
	r1	m	r2										R1 + R2	R2
1/S	0.40	0.40	0.11	✓	0.18	N/A	500	>500	>500	✓	0.23	38.1	✓	✓
2/S	0.16	0.16	0.20	✓	0.14	N/A	500	>500	>500	✓	0.18	38.1	✓	✓
3/S	0.32	0.32	0.23	✓	0.19	N/A	500	>500	>500	✓	0.19	38.1	✓	✓
4/S	0.10	0.10	0.16	✓	0.56	N/A	500	>500	>500	✓	0.31	38.1	✓	✓
5/S	N/A	N/A	N/A	N/A	0.39	N/A	500	>500	>500	✓	0.45	28.5	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		80.6	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		80.6	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.09	N/A	500	>500	>500	✓	0.22	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.05	N/A	500	>500	>500	✓	0.39	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.17	N/A	500	>500	>500	✓	0.36	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.21	N/A	500	>500	>500	✓	0.38	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
13/S	N/A	N/A	N/A	N/A						N/A		70.9	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		70.9	✓	N/A
15/S	N/A	N/A	N/A	N/A	0.32	N/A	500	>500	>500	✓	0.37	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A	2.19	N/A	500	>500	>500	✓	1.27	N/A	N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing: 18/10/2022 To: 31/10/2022

Date(s) live testing: 31/10/2022 To: 18/11/2022

Test instrument serial number(s)

Loop impedance: 233382 Insulation resistance: 233382 Continuity: 233382 RCD: 233382 E/Electrode: n/a

Tested by: Name (capital letters) GARETH DAVIES

Position: Approved Electrician Date: 18/08/2023

Signature: Gareth Davies

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003666

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation

Electrical installation in apartment M06 on mezz level

Extent of the installation covered by this certificate

All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003666

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Declaration for Construction

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022
The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager	
Inspector Name	Paul Clapham	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No. 11922
		Signature	Paul Clapham	
Reviewed By	PD CLAPHAM	Reviewed By	P.D. Clapham	
Reviewed By Date	18/08/2023	Signature		

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022
The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician	
Inspector Name	Gareth Davies	Date	18/08/2023	
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No. 11922
		Signature	Gareth Davies	
Reviewed By	GD	Reviewed By		
Reviewed By Date	18/08/2023	Signature		

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/> if Other please specify	SN-E	
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	88-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003666

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) <input type="text"/>		Means of Earthing	
Location <input type="text"/>	Electrode resistance to earth <input type="text"/> Ω	Distributors facility <input checked="" type="checkbox"/>	Installation Earth Electrode <input type="checkbox"/>
Main Protective Conductors		Maximum Demand (load) <input type="text"/> Amps <input checked="" type="checkbox"/> KVA <input type="checkbox"/>	
Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper 16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	N/A N/A mm ²	Continuity Verified <input type="checkbox"/>	Connection Verified <input type="checkbox"/>
Main Supply Conductor		(connection / continuity) (✓) or Value	
Material	csa	(✓) or Value	(✓) or Value
Copper	16 mm ²	Water installation <input checked="" type="checkbox"/>	To structural steel <input checked="" type="checkbox"/>
Main Switch Location	Utility cupboard in Apartment.	Gas installation pipes <input checked="" type="checkbox"/>	To lightning protection <input checked="" type="checkbox"/>
Fuse/device rating or setting <input type="text"/> A Voltage rating <input type="text"/> V		Oil installation pipes <input checked="" type="checkbox"/>	Other <input type="text"/>
If RCD main switch: Rated residual operating current I _{Δn} <input type="text"/> mA		BS(EN) <input type="text"/>	No. of Poles <input type="text"/>
Rated time delay <input type="text"/> ms		Current Rating <input type="text"/> A	Measured operating trip time <input type="text"/> ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
		NA	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantity of schedules attached) schedules of circuit details and test results are attached

Inspector's Name:

Signature:

Date:

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003666

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details Type(s)†	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit	Supply to distribution board is from <input type="text" value="Main incoming"/>
Location	Utility cupboard in apartment	No. of phases	1 <input type="text"/> BS(EN) <input type="text" value="60947-3"/> Type <input type="text" value="N/A"/> Rating <input type="text" value="100"/> A
Designation	Apartment M06	Nominal voltage	230 <input type="text"/> V RCD BS(EN) <input type="text" value="61008"/> Type <input type="text" value="A"/> Rating <input type="text" value="30"/> Idn mA
No. of ways	18		

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Rcd method ‡	No. of points served	Circuit conductors (sq (mm)²)			Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max permitted Zs (Other than Zs) (Ω)	RCD			
					L / N	CPC	Maximum cross-sectional area (BS 7671) (S)	BS EN Number	Type No	Rating (A)			BS EN Number	Type No	Idn (mA)	Rating (A)
1/S	Store/Hallway sockets	O	0-10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Bedroom/ Living room sockets	O	0-10	7	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Kitchen sockets	O	0-10	3	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance and grid switch	O	0-100	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	0-10	3	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE														30	
7/S	RCD MODULE														30	
8/S	Hob	O	0-10	3	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	N/A
9/S	Immersion/ASHP	O	0-10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	N/A
10/S	Heater	O	0-10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	N/A
11/S	Towel Radiator	O	0-10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	N/A
12/S	SPARE															
13/S	RCD MODULE														30	
14/S	RCD MODULE														30	
15/S	Lighting	O	0-10	24	1.5	1	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	N/A
16/S	SPARE															
17/S	SPARE															
18/S	SPARE															

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/BWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
† Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
§ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results.

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003666

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
Location	Utility cupboard in apartment	Associated RCD (if any):	B5 (EN) 61008
Designation	Apartment M06	Z _s	0.09 Ω Operating at IΔn _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I _n	2.59 kA No. of poles 2 Time delay (if applicable) N/A
No. of phases	1 SPD <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

TEST RESULTS

Circuit No. and Line	Circuit impedance Z				Insulation resistance (Record lower reading)			Polarity	Max Measured Z _s (Ω)	RCD testing All RCDs Δn ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2 R1+R2 R2	Test voltage V	LL, LN M(Ω)	LE, NE M(Ω)				RCD	MCD		
	r1	m	r2										✓	✓
1/S	0.24	0.23	0.15	✓	0.30	N/A	500	>500	>299	✓	0.30	38.2	✓	✓
2/S	0.46	0.46	0.24	✓	0.45	N/A	500	>500	>299	✓	0.30	37.9	✓	✓
3/S	0.18	0.18	0.20	✓	0.15	N/A	500	>500	>299	✓	0.19	38.0	✓	✓
4/S	0.09	0.09	0.15	✓	0.21	N/A	500	>500	>299	✓	0.28	38.2	✓	✓
5/S	N/A	N/A	N/A	N/A	0.49	N/A	250	>500	>299	✓	0.32	28.6	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		69.0	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		69.0	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.24	N/A	500	>299	>299	✓	0.35	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.13	N/A	500	>299	>299	✓	0.53	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.10	N/A	500	>299	>299	✓	0.39	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.16	N/A	500	>299	>299	✓	0.33	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
13/S	N/A	N/A	N/A	N/A						N/A		61.1	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		61.1	✓	N/A
15/S	N/A	N/A	N/A	N/A	1.30	N/A	500	>299	>299	✓	0.92	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing 19/10/2022 To 31/10/2022

Date(s) live testing 31/10/2022 To 18/11/2022

Test instrument serial number(s)

Loop impedance 233382 Insulation resistance 233382 Continuity 233382 RCD 233382 E/Earthcode n/a

Tested by: Name (capital letters) GARETH DAVIES Signature Gareth Davies

Position Approved Electrician Date 18/08/2023

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003667

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
Electrical installation in apartment M07 on mezz level

Extent of the installation covered by this certificate
All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
none

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003667

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022.

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		
Reviewed By	PD CLAPHAM	Reviewed By	P.D. Clapham		
Reviewed By Date	18/08/2023	Reviewed By Signature			

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022.

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Gareth Davies		
Reviewed By	Gareth Davies R.D.	Reviewed By	Gareth Davies		
Reviewed By Date	18/08/2023	Reviewed By Signature			

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _{pf} ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	BS-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003667

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Means of Earthing

Details of Installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc)

Location Electrode resistance to earth Ω

Main Protective Conductors

Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper 16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	N/A N/A mm ²	Continuity Verified <input type="checkbox"/>	Connection Verified <input type="checkbox"/>

Main Supply Conductor Material csa mm²

Main Switch Location

Fuse/device rating or setting A Voltage rating V

If RCD main switch: Rated residual operating current I_{Δn} mA

BS(EN) No. of Poles Current Rating A

Rated time delay ms Measured operating trip time ms

Distributors facility Installation Earth Electrode

Maximum Demand (load) Amps KVA

Water installation To structural steel

Gas installation pipes To lightning protection

Oil installation pipes Other

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name: Signature:

Date:

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003667

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations

BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case

SFD Details: Type(s)* T1 T2 T3 N/A

Location: Utility cupboard in apartment

Designation: Apartment M07

No. of ways: 18

Complete only if the distribution board is not connected directly to the origin of the installation

Overcurrent protective device for the distribution circuit: Supply to distribution board is from: Main incoming

No. of phases: 1 BS(EN) 60947-3 Type N/A Rating 100 A

Nominal voltage: 230 V RCD BS(EN) 61008 Type A Rating 30 IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No and Line	Circuit designation	Type of wiring	Rad. method ¹	No. of points served	Circuit conductors csa (mm ²)			Maximum disconnection time BS 7671 (s)	Overcurrent protective devices			BS EN 60898 capacity (KA)	BS 7671 trip permitted ² Other ³ Other ⁴	RCD			
					L/N	CPC			BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/S	Store/Hallway sockets	O	0-10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A	
2/S	Bedroom/ Living room sockets	O	0-10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A	
3/S	Kitchen sockets	O	0-10	3	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A	
4/S	Kitchen appliance and grid switch	O	0-100	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A	
5/S	Fire Alarm	O	0-10	3	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A	
6/S	RCD MODULE														30		
7/S	RCD MODULE														30		
8/S	Hob	O	0-10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	0-10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	N/A	
10/S	Heater	O	0-10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	N/A	
11/S	Towel Radiator	O	0-10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	N/A	
12/S	SPARE																
13/S	MODULE														30		
14/S	MODULE														30		
15/S	Lighting	O	0-10	23	1.5	1	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	N/A	
16/S	SPARE																
17/S	SPARE																
18/S	SPARE																

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/PLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

* SFD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
¹ Where a T3 SFD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
² See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
³ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results.

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003667

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:

No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD: Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN)
 Z_{in} Ω Operating at I_{dn} mA
 I_n kA No. of poles Time delay (if applicable)

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. measured Z_e (Ω)	RCD testing All RCDs 18n ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R3	Test voltage V	LL, LN M(Ω)	LE, NE M(Ω)				RCD	AFCD		
	r1	m	r2										R1 + R2	R3
1/S	0.25	0.23	0.13	✓	0.15	N/A	500	>500	>299	✓	0.23	37.9	✓	✓
2/S	0.56	0.55	0.40	✓	0.21	N/A	500	>500	>299	✓	0.35	37.8	✓	✓
3/S	0.10	0.10	0.14	✓	0.08	N/A	500	>500	>299	✓	0.18	37.9	✓	✓
4/S	0.08	0.09	0.15	✓	0.15	N/A	500	>500	>299	✓	0.32	37.8	✓	✓
5/S	N/A	N/A	N/A	N/A	0.14	N/A	500	>500	>299	✓	0.55	28.5	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		88.4	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		88.4	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.07	N/A	250	>299	>299	✓	0.20	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.03	N/A	500	>299	>299	✓	0.40	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.14	N/A	500	>299	>299	✓	0.41	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.15	N/A	500	>299	>299	✓	0.42	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			✓	N/A
13/S	N/A	N/A	N/A	N/A						N/A		97.0	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		97.0	✓	N/A
15/S	N/A	N/A	N/A	N/A	1.74	N/A	250	>299	>299	✓	0.91	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing: To:
 Date(s) live testing: To:

Test instrument serial number(s):

Loop impedance: Insulation resistance: Continuity: RCD: E/Earthcode:

Tested by: Name (capital letters) Signature:
 Position: Date:

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003668

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)**Client Details**

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation

Electrical installation in apartment M08 on Mezz level

Extent of the installation covered by this certificate

All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

none

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners.	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova Way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003668

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671: 2018+A2:2022 (IET Wiring Regulations 18th Edition)**Declaration for Construction**

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		


Reviewed By	PD CLAPHAM	Reviewed By Signature	P.D. Clapham
Reviewed By Date	18/08/2023		

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Gareth Davies		

Reviewed By	R.B.D.	Reviewed By Signature	
Reviewed By Date	18/08/2023		

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	88-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003668

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671: 2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility Installation Earth Electrode
 Location Electrode resistance to earth Ω Maximum Demand (load) 80 Amps KVA

Main Protective Conductors Material csa (✓) or Value (✓) or Value
 Earthing Conductor Copper 16 mm² Continuity Verified Ω Connection Verified Ω
 Protective Bonding Conductor N/A N/A mm² Continuity Verified N/A Ω Connection Verified N/A Ω

Main Supply Conductor Material csa (connection / continuity) (✓) or Value (✓) or Value
 Copper 16 mm² Water installation Ω To structural steel Ω
Main Switch Location Utility cupboard in Apartment. Gas installation pipes Ω To lightning protection Ω
 Oil installation pipes Ω Other Ω

Fuse/device rating or setting Switch A Voltage rating 230 V BS(EN) 60947-3 No. of Poles 2 Current Rating 100 A
 If RCD main switch: Rated residual operating current I_{Δn} N/A mA Rated time delay N/A ms Measured operating trip time N/A ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) 1 schedules of circuit details and test results are attached

Inspector's Name: Gareth Davies
 Date: 18/08/2023

Signature: Gareth Davies

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003668

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case

SPO Details: Type(s) T1 T2 T3 N/A

Location:

Designation:

No. of ways:

Complete only if the distribution board is not connected directly to the origin of the installation

Overcurrent protective device for the distribution circuit: Supply to distribution board is from

No. of phases: BS(EN) Type Rating A

Nominal voltage: V RCD BS(EN) Type Rating IΔn mA

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Rat. method ¹	No. of points served	Circuit conductors csa (mm ²)		Maximum disconnection time (s) (EN 61141)	Overcurrent protective devices			Grouping capacity (KA)	BS 7671 Max. permitted Zs (Other than 0.1) (Ω)	RCD			
					L/N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Rating (A)	
1/S	Bed/Store sockets	O	1/10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Kitchen Sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Living Room Sockets	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance grid switches	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	1/10	5	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE														30	
7/S	RCD MODULE														30	
8/S	Hob	O	1/10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	1/10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	
10/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
11/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
12/S	SPARE															
13/S	RCD MODULE														30	
14/S	RCD MODULE														30	
15/S	Towel Radiator	O	1/10	2	2.5	1.5	0.4	60898 MCB	B	16	1	2.73	N/A	N/A	N/A	
16/S	Lighting	O	1/10	26	1.5	1.0	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	
17/S	SPARE															
18/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/PLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

¹ SPO Type: Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
² Where a T3 SPO is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
³ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
⁴ Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003668

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street , Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case

Location:
 Designation:
 No. of ways: Supply polarity confirmed Phase sequence confirmed
 No. of phases: SPD Operational status confirmed Not applicable

Complete only if the distribution board is not connected directly to the origin of the installation

Associated RCD (if any): BS (EN)
 Z_{in} Ω Operating at $I_{\Delta n}$ mA
 $I_{\Delta n}$ kA No. of poles Time delay (if applicable)

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Priority	Max. Measured Z_e (Ω)	RCD testing All RCDs tripped ms	Manual test button operation			
	Ring final circuits only			R1/R2 or R2	Test voltage V	LL, LN M(Ω)	L-E, N-E M(Ω)				RCD	AFDD		
	r1	r2	r3										R1 + R2	R2
1/S	0.36	0.36	0.12	✓	0.15	N/A	500	>500	>500	✓	0.25	37.7	✓	✓
2/S	0.27	0.27	0.34	✓	0.18	N/A	500	>500	>500	✓	0.21	37.9	✓	✓
3/S	0.36	0.36	0.44	✓	0.24	N/A	500	>500	>500	✓	0.34	37.9	✓	✓
4/S	0.21	0.22	0.32	✓	0.20	N/A	500	>500	>500	✓	0.33	37.8	✓	✓
5/S	N/A	N/A	N/A	N/A	0.50	N/A	250	>500	>500	✓	0.62	28.4	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		97.0	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		97.0	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.05	N/A	500	>500	>500	✓	0.32	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.12	N/A	500	>500	>500	✓	0.43	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.12	N/A	500	>500	>500	✓	0.50	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.08	N/A	500	>500	>500	✓	0.45	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
13/S	N/A	N/A	N/A	N/A						N/A		90.3	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		90.3	✓	N/A
15/S	N/A	N/A	N/A	N/A	0.08	N/A	500	>500	>500	✓	0.47	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A	0.87	N/A	250	>500	>500	✓	0.98	N/A	N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A
18/S	N/A	N/A	N/A	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

RCBO'S, AFDD'S, Lamps, USB sockets

Date(s) dead testing: 18/10/2023 To 31/10/2023
 Date(s) live testing: 31/10/2022 To 18/11/2022

Test instrument serial number(s):
 Loop impedance: Insulation resistance: Continuity: RCD: E/Electrode:

Tested by: Name (capital letters) Signature:
 Position: Date:

ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003669

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Details

Client	B E C T Building Contractors Ltd	Installation	Landore Court
Address	Unit 22, Waterside Business Park Lamby Way Rumney Cardiff	Address	Charles street Cardiff
Postcode	CF3 2ET	Postcode	CF10 2GD

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation 01/11/2022

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
Electrical installation in apartment M09 on Mezz level

Extent of the installation covered by this certificate
All electrical services fed from Distribution board local in the apartment.
Small power and lighting, cooker/hob, Smoke detectors, heating/ ventilation

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
none

Details of permitted exception (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
None

Declaration for Design

I being the person responsible for design of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	MCCann and partners	Date	18/08/2023		
Designer Name	Martin Cole	Scheme No.	6889	Branch No.	Cardiff
Address	Faraday House Terra Nova Way, Penarth Marina Cardiff	Signature			
Reviewed By		Reviewed By Signature			
Reviewed By Date	18/08/2023				

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 10 years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003669

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

Declaration for Construction

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Project Manager		
Inspector Name	Paul Clapham	Date	02/01/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Paul Clapham		

Reviewed By	PD Clapham	Reviewed By	P.D. Clapham
Reviewed By Date	18/08/2023	Reviewed By Signature	

Declaration for Inspection and Testing

I being the person responsible for inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2022

The extent of liability of the signatory is limited to work described in Section 2 as subject of this certificate.

Company	Whitehead Building Services Ltd	Position	Approved Electrician		
Inspector Name	Gareth Davies	Date	18/08/2023		
Address	Lanyon House Mission Court Newport NP20 2DW	Scheme No.	NICEIC-11922	Branch No.	11922
		Signature	Gareth Davies		

Reviewed By	Gareth Davies R.D.	Reviewed By	Gareth Davies
Reviewed By Date	18/08/2023	Reviewed By Signature	

Supply Characteristics and Earthing Arrangements

Earthing Arrangements	TN-S <input type="checkbox"/>	TN-C-S <input type="checkbox"/>	TT <input type="checkbox"/>	Other <input checked="" type="checkbox"/>	If Other please specify	SN-E
Number & Type of live conductors	AC <input checked="" type="checkbox"/>	DC <input type="checkbox"/>	No. of phases	1	No. of wires	2
Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)						
Nominal voltage, U _n ⁽¹⁾	230	v	Nominal frequency, f ⁽¹⁾	50	Hz	Confirmation of polarity <input checked="" type="checkbox"/>
Prospective fault current, I _p ⁽²⁾	2.43	kA	External loop impedance, Z _e ⁽²⁾	0.24	Ω	
Supply Protective Device BS (EN)	88-2 HRC gG	Type	gG	Rated Current	80	A
No. of Additional Supplies	N/A					

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 9334000003669

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Particulars of Installation at the Origin

Details of Installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc)

Location Electrode resistance to earth Ω

Means of Earthing
 Distributors facility Installation Earth Electrode
 Maximum Demand (load) 60 Amps KVA

Main Protective Conductors

Material	csa	(<input checked="" type="checkbox"/>) or Value	(<input checked="" type="checkbox"/>) or Value
Earthing Conductor	Copper 16 mm ²	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	N/A	Continuity Verified <input type="checkbox"/> N/A	Connection Verified <input type="checkbox"/> N/A

Main Supply Conductor Material csa mm²

Main Switch Location

Fuse/device rating or setting A Voltage rating V
 If RCD main switch: Rated residual operating current I_{Δn} mA BS(EN) No. of Poles Current Rating A
 Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed
 None- All new install

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory <input checked="" type="checkbox"/>		Indicates the inspection is not applicable to a particular item <input type="checkbox"/>	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name:
 Date:

Signature

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 9334000003669

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Postcode	CF10 2GD
Client Postcode	CF3 2ET		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s)*	T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3 <input type="checkbox"/> N/A <input checked="" type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from: Main Incomer
Location	Utility cupboard in apartment	No. of phases	1 BS(EN) 60947-3 Type N/A Rating 100 A
Designation	Apartment M09	Nominal voltage	230 V RCD BS(EN) 61008 Type A Rating 30 IΔn mA
No. of ways	18		

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Pct. method ¹	No. of points served	Circuit conductors CSA (mm ²)			Maximum disconnection time (s) (BS 7671)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max permitted Zs Other (Ω)	RCD		
					L/N	CPC			BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	Rating (A)
1/S	Bed/Store sockets	O	1/10	8	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
2/S	Kitchen Sockets	O	1/10	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
3/S	Living room sockets	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
4/S	Kitchen appliance grid switches	O	1/10	5	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.37	61009	A	30	N/A
5/S	Fire Alarm	O	1/10	4	1.5	1.0	0.4	61009 RCD/RCBO	B	6	6	7.28	61009	A	30	N/A
6/S	RCD MODULE														30	
7/S	RCD MODULE														30	
8/S	Hob	O	1/10	2	6	2.5	0.4	60898 MCB	C	32	6	0.68	N/A	N/A	N/A	
9/S	Immersion/ASHP	O	1/10	1	2.5	1.5	0.4	60898 MCB	C	20	6	1.09	N/A	N/A	N/A	
10/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
11/S	Heater	O	1/10	1	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
12/S	SPARE															
13/S	RCD MODULE														30	
14/S	RCD MODULE														30	
15/S	Towel Radiator	O	1/10	2	2.5	1.5	0.4	60898 MCB	B	16	6	2.73	N/A	N/A	N/A	
16/S	Lighting	O	1/10	26	1.5	1.0	0.4	60898 MCB	C	6	6	3.64	N/A	N/A	N/A	
17/S	SPARE															
18/S	SPARE															

Wiring Types: A PVC/PVC, B PVC cables in metallic Conduit, C PVC cables in non-metallic Conduit, D PVC cables in metallic trunking, E PVC cables in non-metallic trunking, F PVC/SWA cables, G SWA/PPLE cables, H Mineral Insulated, MW Metal Work, FM Ferrous Metal, O Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 9334000003669

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)

Client Name	B E C T Building Contractors Ltd	Installation Address	Landore Court, Charles street, Cardiff
Client Address	Unit 22, Waterside Business Park, Lamby Way Rumney, Cardiff	Client Postcode	CF3 2ET
		Installation Postcode	CF10 2GD

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
Location	Utility cupboard in apartment	Associated RCD (if any):	BS (EN) 61008
Designation	Apartment M09	Z _s	0.14 Ω Operating at I _{Δn} _____ ms
No. of ways	18 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I _n	1.6 kA No. of poles 2 Time delay (if applicable) N/A
No. of phases	1 SPD <input type="checkbox"/> Operational status confirmed <input checked="" type="checkbox"/> Not applicable		

TEST RESULTS

Circuit No and Line	Circuit impedance Z				Insulation resistance (Record lower reading)			Polarity	Max Resistance Z _s (Ω)	RCD testing at RCDs I _{Δn} ms	Manual test button operation			
	Ring final circuits only			RCD or RCD	Test voltage V	LL, LN M(Ω)	LE, NE M(Ω)				RCD	RCD		
	r1	m	r2										✓	R1 + R2
1/S	0.50	0.50	0.10	✓	0.45	N/A	500	>500	>500	✓	0.27	38.1	✓	✓
2/S	0.21	0.21	0.29	✓	0.44	N/A	500	>500	>500	✓	0.28	38.1	✓	✓
3/S	0.25	0.25	0.28	✓	0.44	N/A	500	>500	>500	✓	0.21	37.9	✓	✓
4/S	0.15	0.15	0.22	✓	0.31	N/A	500	>500	>500	✓	0.23	38.0	✓	✓
5/S	N/A	N/A	N/A	N/A	0.42	N/A	250	>500	>500	✓	0.53	28.4	✓	✓
6/S	N/A	N/A	N/A	N/A						N/A		88.4	✓	N/A
7/S	N/A	N/A	N/A	N/A						N/A		88.4	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.30	N/A	500	>500	>500	✓	0.27	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	0.32	N/A	500	>500	>500	✓	0.36	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	0.28	N/A	500	>500	>500	✓	0.42	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	0.21	N/A	500	>500	>500	✓	0.42	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A						N/A				
13/S	N/A	N/A	N/A	N/A						N/A		61.7	✓	N/A
14/S	N/A	N/A	N/A	N/A						N/A		61.7	✓	N/A
15/S	N/A	N/A	N/A	N/A	0.12	N/A	500	>500	>500	✓	0.37	N/A	N/A	N/A
16/S	N/A	N/A	N/A	N/A	1.14	N/A	500	>500	>500	✓	0.92	N/A	N/A	N/A
17/S	N/A	N/A	N/A	N/A						N/A				
18/S	N/A	N/A	N/A	N/A						N/A				

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	18/10/2022	To	31/10/2022
RCBO'S, AFDD'S, Lamps, USB sockets		Date(s) live testing	31/10/2022	To	18/11/2022
Test instrument serial number(s)					
Loop impedance	233382	Insulation resistance	233382	Continuity	233382
		RCD	233382	E/Earthed	n/a
Tested by: Name (capital letters)	GARETH DAVIES		Signature	Gareth Davies	
Position	Approved Electrician	Date	18/08/2023		